

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement and relining to SIP main canal from Ch. 9.08 km to Ch. 9.11 km & other repair work in Curchorem Constituency.

SAMPLE SENT BY: AE, SD I, WD X, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.36/05/2025						115.56		No. WRD/WD X/ SD I/
	F.36/06/2025	21-11-2025	22-12-2025	RCC Canal lining	1.3.6	100 kg/cm2	111.11	111.11	F. 55 A/ 215 /2025-26.
	F.36/07/2025						106.67		DATED: 24-11-2025
1.2	F.36/08/2025						111.11		
	F.36/09/2025	21-11-2025	22-12-2025	RCC Canal lining	1.3.6	100 kg/cm2	106.67	114.07	
	F.36/10/2025						124.44		
1.3	F.36/11/2025						115.56		
	F.36/12/2025	21-11-2025	22-12-2025	RCC Canal lining	1.3.6	100 kg/cm2	102.22	108.15	
	F.36/13/2025						106.67		
1.4	F.36/14/2025						106.67		
	F.36/15/2025	21-11-2025	22-12-2025	RCC Canal lining	1.3.6	100 kg/cm2	106.67	109.63	
	F.36/16/2025						115.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Improvement and relining to SIP main canal from Ch. 9.08 km to Ch. 9.11 km & other repair work in Curchorem Constituency.

SAMPLE SENT BY: AE, SD I, WD X, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
2.1	F.36/17/2025						280.00		No. WRD/WD X/ SD I/ F. 55 A/ 216 /2025-26. DATED: 25-11-2025
	F.36/18/2025	24-11-2025	22-12-2025	RCC Canal lining	1.1.5.3	265kg/cm2	284.44	281.48	
	F.36/19/2025						280.00		
2.2	F.36/20/2025						288.89		
	F.36/21/2025	24-11-2025	22-12-2025	RCC Canal lining	1.1.5.3	265kg/cm2	275.56	280.00	
	F.36/22/2025						275.56		
2.3	F.36/23/2025						266.67		
	F.36/24/2025	24-11-2025	22-12-2025	RCC Canal lining	1.1.5.3	265kg/cm2	284.44	277.04	
	F.36/25/2025						280.00		
2.4	F.36/26/2025						288.89		
	F.36/27/2025	24-11-2025	22-12-2025	RCC Canal lining	1.1.5.3	265kg/cm2	284.44	281.48	
	F.36/28/2025						271.11		
2.5	F.36/29/2025						280.00		
	F.36/30/2025	24-11-2025	22-12-2025	RCC Canal lining	1.1.5.3	265kg/cm2	284.44	282.96	
	F.36/31/2025						284.44		
2.6	F.36/32/2025						266.67		
	F.36/33/2025	24-11-2025	22-12-2025	RCC Canal lining	1.1.5.3	265kg/cm2	280.00	278.52	
	F.36/34/2025						288.89		
2.7	F.36/35/2025						288.89		
	F.36/36/2025	24-11-2025	22-12-2025	RCC Canal lining	1.1.5.3	265kg/cm2	284.44	285.92	
	F.36/37/2025						284.44		
2.8	F.36/38/2025						284.44		
	F.36/39/2025	24-11-2025	22-12-2025	RCC Canal lining	1.1.5.3	265kg/cm2	288.89	284.44	
	F.36/40/2025						280.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER