

NO.WRD/WDXI/SDIII/TECH/W.F.85/2024/2024-25/ 443 . Dated:-29/3/25

GOVERNMENT OF GOA

**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Improvement of nallah bank behind Anant Laxmi building in ward No.4 Yeshwant Nagar in Ponda Constituency of Taluka Ponda.

**SAMPLE SENT BY:** AE, SD IV, WD XI, WRD, Ponda- Goa.

| NAME OF THE AGENCY |               |              |              | TESTING PERIOD     |                  | 28 days.           |                       |                     |                           |
|--------------------|---------------|--------------|--------------|--------------------|------------------|--------------------|-----------------------|---------------------|---------------------------|
| REPORT NO          | SAMPLE NOS.   | CASTING DATE | TESTING DATE | LOCATION OF SAMPLE | MIX<br>PROPOTION | TARGET<br>STRENGTH | Comp sth in<br>Kg/cm2 | Avg. Comp<br>Kg/cm2 | LETTER No / DATED         |
| 1.1                | F. 85/11/2024 |              |              |                    |                  |                    | 231.11                |                     | No. WRD/WD XI/ SD IV/     |
|                    | F. 85/12/2024 | 17-02-2025   | 17-03-2025   | Foundation         | 1.2.4            | 210 kg/cm2         | 226.67                | 228.15              | F.CF/682/2024-25.         |
|                    | F. 85/13/2024 |              |              |                    |                  |                    | 226.67                |                     | <b>DATED: 17-03-2025.</b> |
| 1.2                | F. 85/14/2024 |              |              |                    |                  |                    | 235.56                |                     |                           |
|                    | F. 85/15/2024 | 17-02-2025   | 17-03-2025   | Foundation         | 1.2.4            | 210 kg/cm2         | 231.11                | 229.63              | do                        |
|                    | F. 85/16/2024 |              |              |                    |                  |                    | 222.22                |                     |                           |
| 2.1                | F. 85/17/2024 |              |              |                    |                  |                    | 235.56                |                     |                           |
|                    | F. 85/18/2024 | 18-02-2025   | 18-03-2025   | Foundation         | 1.2.4            | 210 kg/cm2         | 226.67                | 229.63              | do                        |
|                    | F. 85/19/2024 |              |              |                    |                  |                    | 226.67                |                     |                           |
| 2.2                | F. 85/20/2024 |              |              |                    |                  |                    | 222.22                |                     |                           |
|                    | F. 85/21/2024 | 18-02-2025   | 18-03-2025   | Foundation         | 1.2.4            | 210 kg/cm2         | 235.56                | 232.59              | do                        |
|                    | F. 85/22/2024 |              |              |                    |                  |                    | 240.00                |                     |                           |
| 3.1                | F. 85/23/2024 |              |              |                    |                  |                    | 231.11                |                     |                           |
|                    | F. 85/24/2024 | 20-02-2025   | 20-03-2025   | Foundation         | 1.2.4            | 210 kg/cm2         | 226.67                | 228.15              | do                        |
|                    | F. 85/25/2024 |              |              |                    |                  |                    | 226.67                |                     |                           |
| 3.2                | F. 85/26/2024 |              |              |                    |                  |                    | 231.11                |                     |                           |
|                    | F. 85/27/2024 | 20-02-2025   | 20-03-2025   | Foundation         | 1.2.4            | 210 kg/cm2         | 235.56                | 229.63              | do                        |
|                    | F. 85/28/2024 |              |              |                    |                  |                    | 222.22                |                     |                           |
| 3.2                | F. 85/29/2024 |              |              |                    |                  |                    | 240.00                |                     |                           |
|                    | F. 85/30/2024 | 20-02-2025   | 20-03-2025   | Foundation         | 1.2.4            | 210 kg/cm2         | 231.11                | 231.11              | do                        |
|                    | F. 85/31/2024 |              |              |                    |                  |                    | 222.22                |                     |                           |
| 4.1                | F. 85/32/2024 |              |              |                    |                  |                    | 222.22                |                     |                           |
|                    | F. 85/33/2024 | 22-02-2025   | 22-03-2025   | Wall 1st Lift      | 1.2.4            | 210 kg/cm2         | 226.67                | 226.67              | do                        |
|                    | F. 85/34/2024 |              |              |                    |                  |                    | 231.11                |                     |                           |

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Improvement of nallah bank behind Anant Laxmi building in ward No.4 Yeshwant Nagar in Ponda Constituency of Taluka Ponda.

**SAMPLE SENT BY:** AE, SD IV, WD XI, WRD, Ponda- Goa.

| NAME OF THE AGENCY |               |              |              |                    | TESTING PERIOD   |                    | 28 days.              |                     |                                                                                  |
|--------------------|---------------|--------------|--------------|--------------------|------------------|--------------------|-----------------------|---------------------|----------------------------------------------------------------------------------|
| REPORT NO          | SAMPLE NOS.   | CASTING DATE | TESTING DATE | LOCATION OF SAMPLE | MIX<br>PROPOTION | TARGET<br>STRENGTH | Comp sth in<br>Kg/cm2 | Avg. Comp<br>Kg/cm2 | LETTER No / DATED                                                                |
| 4.2                | F. 85/35/2024 |              |              |                    |                  |                    | 231.11                |                     | No. WRD/WD XI/ SD IV/<br>F.CF/ <b>682</b> /2024-25.<br><b>DATED: 17-03-2025.</b> |
|                    | F. 85/36/2024 | 22-02-2025   | 22-03-2025   | Wall 1st Lift      | 1.2.4            | 210 kg/cm2         | 217.78                | 226.67              |                                                                                  |
|                    | F. 85/37/2024 |              |              |                    |                  |                    | 231.11                |                     |                                                                                  |
| 4.3                | F. 85/38/2024 |              |              |                    |                  |                    | 226.67                |                     |                                                                                  |
|                    | F. 85/39/2024 | 22-02-2025   | 22-03-2025   | Wall 1st Lift      | 1.2.4            | 210 kg/cm2         | 235.56                | 225.19              | do                                                                               |
|                    | F. 85/40/2024 |              |              |                    |                  |                    | 213.33                |                     |                                                                                  |
| 5.1                | F. 85/41/2024 |              |              |                    |                  |                    | 235.56                |                     |                                                                                  |
|                    | F. 85/42/2024 | 23-02-2025   | 23-03-2025   | Wall 1st Lift      | 1.2.4            | 210 kg/cm2         | 231.11                | 226.67              | do                                                                               |
|                    | F. 85/43/2024 |              |              |                    |                  |                    | 213.33                |                     |                                                                                  |
| 5.2                | F. 85/44/2024 |              |              |                    |                  |                    | 213.33                |                     |                                                                                  |
|                    | F. 85/45/2024 | 23-02-2025   | 23-03-2025   | Wall 1st Lift      | 1.2.4            | 210 kg/cm2         | 231.11                | 223.70              | do                                                                               |
|                    | F. 85/46/2024 |              |              |                    |                  |                    | 226.67                |                     |                                                                                  |
| 5.3                | F. 85/47/2024 |              |              |                    |                  |                    | 235.56                |                     |                                                                                  |
|                    | F. 85/48/2024 | 23-02-2025   | 23-03-2025   | Wall 1st Lift      | 1.2.4            | 210 kg/cm2         | 217.78                | 222.22              | do                                                                               |
|                    | F. 85/49/2024 |              |              |                    |                  |                    | 213.33                |                     |                                                                                  |
| 6.1                | F. 85/50/2024 |              |              |                    |                  |                    | 226.67                |                     |                                                                                  |
|                    | F. 85/51/2024 | 25-02-2025   | 25-03-2025   | Wall 2nd Lift      | 1.2.4            | 210 kg/cm2         | 213.33                | 226.67              | do                                                                               |
|                    | F. 85/52/2024 |              |              |                    |                  |                    | 240.00                |                     |                                                                                  |
| 6.2                | F. 85/53/2024 |              |              |                    |                  |                    | 222.22                |                     |                                                                                  |
|                    | F. 85/54/2024 | 25-02-2025   | 25-03-2025   | Wall 2nd Lift      | 1.2.4            | 210 kg/cm2         | 217.78                | 225.19              | do                                                                               |
|                    | F. 85/55/2024 |              |              |                    |                  |                    | 235.56                |                     |                                                                                  |
| 6.3                | F. 85/56/2024 |              |              |                    |                  |                    | 240.00                |                     |                                                                                  |
|                    | F. 85/57/2024 | 25-02-2025   | 25-03-2025   | Wall 2nd Lift      | 1.2.4            | 210 kg/cm2         | 217.78                | 228.15              | do                                                                               |
|                    | F. 85/58/2024 |              |              |                    |                  |                    | 226.67                |                     |                                                                                  |

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**