

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Access on nallah passing along Assolna to Betul road in Village Assolna in Salcete Taluka.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.86/05/2023						231.11		No.WRD/SD I/ WDII/ F.Esst/06/2024-25. DATED: 04-04-2024
	F.86/06/2023	15-03-2024	12/4/2024		1.2.4	210 kg/cm2	217.78	226.67	
	F.86/07/2023						231.11		
1.2	F.86/08/2023						231.11		do
	F.86/09/2023	15-03-2024	12/4/2024		1.2.4	210 kg/cm2	213.33	225.18	
	F.86/10/2023						231.11		
2.1	F.86/11/2023						231.11		do
	F.86/12/2023	18-03-2024	15-04-2024		1.2.4	210 kg/cm2	222.22	223.70	
	F.86/13/2023						217.78		
2.2	F.86/14/2023						222.22		do
	F.86/15/2023	18-03-2024	15-04-2024		1.2.4	210 kg/cm2	231.11	226.67	
	F.86/16/2023						226.67		
3	F.86/17/2023						222.22		do
	F.86/18/2023	22-03-2024	19-04-2024		1.2.4	210 kg/cm2	231.11	225.18	
	F.86/19/2023						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER