

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Providing RCC Canal Lining to Minor M1 Canal from Ch 2400 to 2980 mts in Cacora Village of Quepem Taluka.

SAMPLE SENT BY: AE, SD I, WD X, WRD, Quepem-Goa.

NAME OF THE AGENCY : M/s Ashko Builders, Navelim, Goa.

TESTING PERIOD

07 days.

| REPORT NO | SAMPLE NOS. | CASTING DATE | TESTING DATE | LOCATION OF SAMPLE | MIX PROPOTION | REQUIRED STRENGTH | Comp sth in Kg/cm2 | Avg. Comp Kg/cm2 | LETTER No / DATED |
|-----------|-------------|--------------|--------------|-----------------------------|---------------|-------------------|--------------------|------------------|-------------------|
| | 346 | | | | | | 173.33 | | No. WRD/WD X |
| 1 | 347 | 16-11-2019 | 23-11-2019 | 7.50 cm R.C.C Canal Lining. | 1.1.5.3 | 175 kg/cm2 | 177.78 | 176.30 | /SD I/WF.10/154/ |
| | 348 | | | | | | 177.78 | | 2019-20 |
| | 349 | | | | | | 177.78 | | Dt.19/11/2019 |
| 2 | 350 | 16-11-2019 | 23-11-2019 | 7.50 cm R.C.C Canal Lining. | 1.1.5.3 | 175 kg/cm2 | 173.33 | 176.30 | do |
| | 351 | | | | | | 177.78 | | |
| | 352 | | | | | | 182.22 | | |
| 3 | 353 | 18-11-2019 | 25-11-2019 | 7.50 cm R.C.C Canal Lining. | 1.1.5.3 | 175 kg/cm2 | 182.22 | 180.74 | do |
| | 354 | | | | | | 177.78 | | |
| | 355 | | | | | | 182.22 | | |
| 4 | 356 | 18-11-2019 | 25-11-2019 | 7.50 cm R.C.C Canal Lining. | 1.1.5.3 | 175 kg/cm2 | 186.67 | 183.70 | do |
| | 357 | | | | | | 182.22 | | |
| | 370 | | | | | | 182.22 | | |
| 5 | 371 | 20-11-2019 | 27-11-2019 | 7.50 cm R.C.C Canal Lining. | 1.1.5.3 | 175 kg/cm2 | 182.22 | 182.22 | No. WRD/WD X |
| | 372 | | | | | | 182.22 | | /SD I/WF.10/155/ |
| | 373 | | | | | | 182.22 | | 2019-20 |
| 6 | 374 | 20-11-2019 | 27-11-2019 | 7.50 cm R.C.C Canal Lining. | 1.1.5.3 | 175 kg/cm2 | 186.67 | 183.70 | Dt.21/11/2019 |
| | 375 | | | | | | 182.22 | | |

TECHNICAL ASSISTANT
(Dhananjay R. Nagvenkar)

ASSISTANT ENGINEER
(Pravin C. Parsekar)