

NO.WRD/WDXI/SDIII/TECH/W.F.63/2025/2026-27/527
GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

Dated:-14/01/2026

NAME OF THE WORK: Improvement to Dhada Talli at Shirshirem in V.P. Borim of Shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.63/06/2025						226.67		No. WRD/WDXI/SDIV/
	F.63/07/2025	28-11-2025	26-12-2025	Cut off	1.2.4	210 kg/cm2	222.22	226.67	WF.694/ 604 /2025-26.
	F.63/08/2025						231.11		DATED: 18-12-2025
1.2	F.63/09/2025						231.11		
	F.63/10/2025	28-11-2025	26-12-2025	Cut off	1.2.4	210 kg/cm2	213.33	225.18	do
	F.63/11/2025						231.11		
1.3	F.63/12/2025						222.22		
	F.63/13/2025	28-11-2025	26-12-2025	Cut off	1.2.4	210 kg/cm2	231.11	226.67	do
	F.63/14/2025						226.67		
1.4	F.63/15/2025						217.78		
	F.63/16/2025	28-11-2025	26-12-2025	Cut off	1.2.4	210 kg/cm2	222.22	223.70	do
	F.63/17/2025						231.11		
2.1	F.63/18/2025						222.22		
	F.63/19/2025	30-11-2025	29-12-2025	Cut off	1.2.4	210 kg/cm2	213.33	222.22	do
	F.63/20/2025						231.11		
2.2	F.63/21/2025						231.11		
	F.63/22/2025	30-11-2025	29-12-2025	Cut off	1.2.4	210 kg/cm2	226.67	226.67	do
	F.63/23/2025						222.22		
2.3	F.63/24/2025						222.22		
	F.63/25/2025	30-11-2025	29-12-2025	Cut off	1.2.4	210 kg/cm2	222.22	225.18	do
	F.63/26/2025						231.11		
2.4	F.63/27/2025						217.78		
	F.63/28/2025	30-11-2025	29-12-2025	Cut off	1.2.4	210 kg/cm2	240.00	223.70	do
	F.63/29/2025						213.33		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to Dhada Talli at Shirshirem in V.P. Borim of Shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
3.1	F.63/30/2025						231.11		No. WRD/WDXI/SDIV/ WF.694/ 604 /2025-26. DATED: 18-12-2025
	F.63/31/2025	2/12/2025	30-12-2025	Cut off	1.2.4	210 kg/cm2	213.33	226.67	
	F.63/32/2025						235.56		
3.2	F.63/33/2025						231.11		
	F.63/34/2025	2/12/2025	30-12-2025	Cut off	1.2.4	210 kg/cm2	226.67	223.70	do
	F.63/35/2025						213.33		
3.3	F.63/33/2025						222.22		
	F.63/34/2025	2/12/2025	30-12-2025	Cut off	1.2.4	210 kg/cm2	213.33	222.22	do
	F.63/35/2025						231.11		
3.4	F.63/36/2025						235.56		
	F.63/37/2025	2/12/2025	30-12-2025	Cut off	1.2.4	210 kg/cm2	217.78	226.67	do
	F.63/38/2025						226.67		
4.1	F.63/39/2025						235.56		
	F.63/40/2025	5/12/2025	2/1/2026	Foundation	1.2.4	210 kg/cm2	231.11	228.15	do
	F.63/41/2025						217.78		
4.2	F.63/42/2025						222.22		
	F.63/43/2025	5/12/2025	2/1/2026	Foundation	1.2.4	210 kg/cm2	231.11	226.67	do
	F.63/44/2025						226.67		
5.1	F.63/45/2025						235.56		
	F.63/46/2025	6/12/2025	3/1/2026	Foundation	1.2.4	210 kg/cm2	217.78	228.15	do
	F.63/47/2025						231.11		
5.2	F.63/48/2025						222.22		
	F.63/49/2025	6/12/2025	3/1/2026	Foundation	1.2.4	210 kg/cm2	226.67	226.67	do
	F.63/50/2025						231.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to Dhada Talli at Shirshirem in V.P. Borim of Shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.3	F.63/51/2025						222.22		No. WRD/WDXI/SDIV/
	F.63/52/2025	6/12/2025	3/1/2026	Foundation	1.2.4	210 kg/cm2	235.56	229.63	WF.694/ 604 /2025-26.
	F.63/53/2025						231.11		DATED: 18-12-2025
5.4	F.63/54/2025						226.67		
	F.63/55/2025	6/12/2025	3/1/2026	Foundation	1.2.4	210 kg/cm2	235.56	231.11	do
	F.63/56/2025						231.11		
6.1	F.63/57/2025						231.11		
	F.63/58/2025	8/12/2025	5/1/2026	Foundation	1.2.4	210 kg/cm2	235.56	229.63	do
	F.63/59/2025						222.22		
6.2	F.63/57/2025						226.67		
	F.63/58/2025	8/12/2025	5/1/2026	Foundation	1.2.4	210 kg/cm2	231.11	228.15	do
	F.63/59/2025						226.67		
6.3	F.63/57/2025						222.22		
	F.63/58/2025	8/12/2025	5/1/2026	Foundation	1.2.4	210 kg/cm2	231.11	228.15	do
	F.63/59/2025						231.11		
6.4	F.63/57/2025						235.56		
	F.63/58/2025	8/12/2025	5/1/2026	Foundation	1.2.4	210 kg/cm2	231.11	229.63	do
	F.63/59/2025						222.22		
7.1	F.63/57/2025						226.67		
	F.63/58/2025	10/12/2025	7/1/2026	1st Lift	1.2.4	210 kg/cm2	231.11	225.19	do
	F.63/59/2025						217.78		
7.2	F.63/57/2025						217.78		
	F.63/58/2025	10/12/2025	7/1/2026	1st Lift	1.2.4	210 kg/cm2	213.33	223.70	do
	F.63/59/2025						240.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to Dhada Talli at Shirshirem in V.P. Borim of Shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
9.4	F.63/84/2025						217.78		No. WRD/WDXI/SDIV/
	F.63/85/2025	12/12/2025	9/1/2026	1st Lift	1.2.4	210 kg/cm2	222.22	223.70	WF.694/ 604 /2025-26.
	F.63/86/2025						231.11		DATED: 18-12-2025
10.1	F.63/87/2025						222.22		
	F.63/88/2025	15-12-2025	12/1/2026	2nd Lift & Abutment	1.2.4	210 kg/cm2	213.33	222.22	do
	F.63/89/2025						231.11		
10.2	F.63/90/2025						231.11		
	F.63/91/2025	15-12-2025	12/1/2026	2nd Lift & Abutment	1.2.4	210 kg/cm2	226.67	226.67	do
	F.63/92/2025						222.22		
11.1	F.63/93/2025						222.22		
	F.63/94/2025	17-12-2025	14-01-2026	Abutment, Pier 2nd Lift	1.2.4	210 kg/cm2	222.22	225.18	do
	F.63/95/2025						231.11		
11.2	F.63/96/2025						217.78		
	F.63/97/2025	17-12-2025	14-01-2026	Abutment, Pier 2nd Lift	1.2.4	210 kg/cm2	240.00	223.70	do
	F.63/98/2025						213.33		

JUNIOR ENGINEER.

ASSISTANT ENGINEER