

NO.WRD/WDXI/SDIII/TECH/W.F.84-Oct-2025/2025-26/591 . Dated:-21/02/26

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Flood control and safety measures by construction RHS nallah banka at ward ward No. 7 Vazem in V.P. Shiroda of Ponda Taluka.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.84/11/2025						226.67		No. WRD/WD XI/SD IV/ F.630/683/2025-26. DATED: 27-01-2026.
	F.84/12/2025	30-12-2025	27-01-2026	Foundation	1.2.4	210 kg/cm2	226.67	229.63	
	F.84/13/2025						235.56		
1.2	F.84/14/2025						231.11		
	F.84/15/2025	30-12-2025	27-01-2026	Foundation	1.2.4	210 kg/cm2	222.22	228.15	do
	F.84/16/2025						231.11		
1.3	F.84/17/2025						226.67		
	F.84/18/2025	30-12-2025	27-01-2026	Foundation	1.2.4	210 kg/cm2	240.00	228.15	do
	F.84/19/2025						217.78		
2.1	F.84/20/2025						231.11		
	F.84/21/2025	1/1/2026	29-01-2026	Foundation	1.2.4	210 kg/cm2	231.11	229.63	do
	F.84/22/2025						226.67		
2.2	F.84/23/2025						235.56		
	F.84/24/2025	1/1/2026	29-01-2026	Foundation	1.2.4	210 kg/cm2	213.33	226.67	do
	F.84/25/2025						231.11		
2.3	F.84/26/2025						231.11		
	F.84/27/2025	1/1/2026	29-01-2026	Foundation	1.2.4	210 kg/cm2	231.11	228.15	do
	F.84/28/2025						222.22		
3.1	F.84/29/2025						222.22		
	F.84/30/2025	2/1/2026	31-01-2026	Foundation	1.2.4	210 kg/cm2	231.11	229.63	do
	F.84/31/2025						235.56		
3.2	F.84/32/2025						240.00		
	F.84/33/2025	2/1/2026	31-01-2026	Foundation	1.2.4	210 kg/cm2	204.44	226.67	do
	F.84/34/2025						235.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Flood control and safety measures by construction RHS nallah banka at ward ward No. 7 Vazem in V.P. Shiroda of Ponda Taluka.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY					TESTING PERIOD		28 days.		
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
3.3	F.84/35/2025						226.67		No. WRD/WD XI/SD IV/ F.630/ 683 /2025-26. DATED: 27-01-2026.
	F.84/36/2025	2/1/2026	31-01-2026	Foundation	1.2.4	210 kg/cm2	231.11	229.63	
	F.84/37/2025						231.11		
4.1	F.84/38/2025						235.56		
	F.84/39/2025	5/1/2026	2/2/2026	Wall 1st Lift	1.2.4	210 kg/cm2	222.22	226.67	do
	F.84/40/2025						222.22		
4.2	F.84/41/2025						231.11		
	F.84/42/2025	5/1/2026	2/2/2026	Wall 1st Lift	1.2.4	210 kg/cm2	235.56	226.67	do
	F.84/43/2025						213.33		
4.3	F.84/44/2025						226.67		
	F.84/45/2025	5/1/2026	2/2/2026	Wall 1st Lift	1.2.4	210 kg/cm2	226.67	225.19	do
	F.84/46/2025						222.22		
5.1	F.84/47/2025						231.11		
	F.84/49/2025	7/1/2026	4/2/2026	Wall 1st Lift	1.2.4	210 kg/cm2	222.22	226.67	do
	F.84/50/2025						226.67		
5.2	F.84/51/2025						231.11		
	F.84/52/2025	7/1/2026	4/2/2026	Wall 1st Lift	1.2.4	210 kg/cm2	213.33	225.18	do
	F.84/53/2025						231.11		
5.3	F.84/54/2025						226.67		
	F.84/55/2025	7/1/2026	4/2/2026	Wall 1st Lift	1.2.4	210 kg/cm2	226.67	226.67	do
	F.84/56/2025						226.67		
6.1	F.84/57/2025						222.22		
	F.84/58/2025	10/1/2026	7/2/2026	Wall 1st Lift	1.2.4	210 kg/cm2	231.11	223.70	do
	F.84/59/2025						217.78		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Flood control and safety measures by construction RHS nallah banka at ward ward No. 7 Vazem in V.P. Shiroda of Ponda Taluka.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
6.2	F.84/60/2025						226.67		No. WRD/WD XI/SD IV/ F.630/683/2025-26. DATED: 27-01-2026.
	F.84/61/2025	10/1/2026	7/2/2026	Wall 1st Lift	1.2.4	210 kg/cm2	231.11	226.67	
	F.84/62/2025						222.22		
6.3	F.84/63/2025						217.78		
	F.84/64/2025	10/1/2026	7/2/2026	Wall 1st Lift	1.2.4	210 kg/cm2	231.11	225.19	do
	F.84/65/2025						226.67		
7.1	F.84/66/2025						231.11		
	F.84/67/2025	13-01-2026	10/2/2026	Wall 2nd Lift	1.2.4	210 kg/cm2	231.11	226.67	do
	F.84/68/2025						217.78		
7.2	F.84/69/2025						231.11		
	F.84/70/2025	13-01-2026	10/2/2026	Wall 2nd Lift	1.2.4	210 kg/cm2	213.33	225.18	do
	F.84/71/2025						231.11		
7.3	F.84/72/2025						235.56		
	F.84/73/2025	13-01-2026	10/2/2026	Wall 2nd Lift	1.2.4	210 kg/cm2	222.22	226.67	do
	F.84/74/2025						222.22		
8.1	F.84/75/2025						226.67		
	F.84/76/2025	15-01-2026	12/2/2026	Wall 2nd Lift	1.2.4	210 kg/cm2	213.33	223.70	do
	F.84/77/2025						231.11		
8.2	F.84/78/2025						231.11		
	F.84/79/2025	15-01-2026	12/2/2026	Wall 2nd Lift	1.2.4	210 kg/cm2	222.22	225.18	do
	F.84/80/2025						222.22		
8.3	F.84/81/2025						235.56		
	F.84/82/2025	15-01-2026	12/2/2026	Wall 2nd Lift	1.2.4	210 kg/cm2	217.78	223.71	do
	F.84/83/2025						217.78		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Flood control and safety measures by construction RHS nallah banka at ward ward No. 7 Vazem in V.P. Shiroda of Ponda Taluka.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
9.1	F.84/84/2025						231.11		No. WRD/WD XI/SD IV/
	F.84/85/2025	17-01-2026	16-02-2026	Wall 3rd Lift	1.2.4	210 kg/cm2	231.11	225.18	F.630/683/2025-26.
	F.84/86/2025						213.33		DATED: 27-01-2026.
9.2	F.84/87/2025						235.56		
	F.84/88/2025	17-01-2026	16-02-2026	Wall 3rd Lift	1.2.4	210 kg/cm2	222.22	226.67	do
	F.84/89/2025						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER