

NO.WRD/WDXI/SDIII/TECH/W.F.95/2025/2025-26/600

Dated:-28/02/2026

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to Irrigation tank/ spring in Sy.No. 70 Village Candepar, ward No. 2 Panchame in V.P. Curti Khandepar in Ponda Taluka.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.95/06/2025						235.56		No. WRD/WD XI/ SD IV/ W.F 677/ 700 /2025-26. DATED: 02-02-2026.
	F.95/07/2025	9/1/2026	6/2/2026	Tank Foundation	1.2.4	210 kg/cm2	231.11	229.63	
	F.95/08/2025						222.22		
1.2	F.95/09/2025						231.11		
	F.95/10/2025	9/1/2026	6/2/2026	Tank Foundation	1.2.4	210 kg/cm2	222.22	226.67	do
	F.95/11/2025						226.67		
1.3	F.95/12/2025						240.00		
	F.95/13/2025	9/1/2026	6/2/2026	Tank Foundation	1.2.4	210 kg/cm2	222.22	228.15	do
	F.95/14/2025						222.22		
2.1	F.95/15/2025						240.00		
	F.95/16/2025	10/1/2026	7/2/2026	Tank Foundation	1.2.4	210 kg/cm2	222.22	228.15	do
	F.95/17/2025						222.22		
2.2	F.95/18/2025						235.56		
	F.95/19/2025	10/1/2026	7/2/2026	Tank Foundation	1.2.4	210 kg/cm2	222.22	226.67	do
	F.95/20/2025						222.22		
2.3	F.95/21/2025						231.11		
	F.95/22/2025	10/1/2026	7/2/2026	Tank Foundation	1.2.4	210 kg/cm2	231.11	228.15	do
	F.95/23/2025						222.22		
3.1	F.95/24/2025						235.56		
	F.95/25/2025	12/1/2026	9/2/2026	Tank Foundation	1.2.4	210 kg/cm2	222.22	226.67	do
	F.95/26/2025						222.22		
3.2	F.95/27/2025						231.11		
	F.95/28/2025	12/1/2026	9/2/2026	Tank Foundation	1.2.4	210 kg/cm2	231.11	228.15	do
	F.95/29/2025						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to Irrigation tank/ spring in Sy.No. 70 Village Candepar, ward No. 2 Panchame in V.P. Curti Khandepar in Ponda Taluka.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
3.3	F.95/30/2025						231.11		No. WRD/WD XI/ SD IV/ W.F 677/ 700 /2025-26. DATED: 02-02-2026.
	F.95/31/2025	12/1/2026	9/2/2026	Tank Foundation	1.2.4	210 kg/cm2	235.56	231.11	
	F.95/32/2025						226.67		
4.1	F.95/33/2025						231.11		
	F.95/34/2025	13-01-2026	10/2/2026	Tank Foundation	1.2.4	210 kg/cm2	226.67	229.63	do
	F.95/35/2025						231.11		
4.2	F.95/36/2025						240.00		
	F.95/37/2025	13-01-2026	10/2/2026	Tank Foundation	1.2.4	210 kg/cm2	222.22	228.15	do
	F.95/38/2025						222.22		
5.1	F.95/39/2025						235.56		
	F.95/40/2025	14-01-2026	11/2/2026	Tank Foundation	1.2.4	210 kg/cm2	235.56	231.11	do
	F.95/41/2025						222.22		
5.2	F.95/42/2025						231.11		
	F.95/43/2025	14-01-2026	11/2/2026	Tank Foundation	1.2.4	210 kg/cm2	226.67	228.15	do
	F.95/44/2025						226.67		
6.1	F.95/45/2025						231.11		
	F.95/46/2025	15-01-2026	12/2/2026	1st Lift of Tank	1.2.4	210 kg/cm2	235.56	229.63	do
	F.95/47/2025						222.22		
6.2	F.95/48/2025						240.00		
	F.95/49/2025	15-01-2026	12/2/2026	1st Lift of Tank	1.2.4	210 kg/cm2	217.78	226.67	do
	F.95/50/2025						222.22		
6.3	F.95/51/2025						231.11		
	F.95/52/2025	15-01-2026	12/2/2026	1st Lift of Tank	1.2.4	210 kg/cm2	222.22	225.18	do
	F.95/53/2025						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to Irrigation tank/ spring in Sy.No. 70 Village Candepar, ward No. 2 Panchame in V.P. Curti Khandepar in Ponda Taluka.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
7.1	F.95/54/2025						235.56		No. WRD/WD XI/ SD IV/ W.F 677/ 700 /2025-26. DATED: 02-02-2026.
	F.95/55/2025	16-01-2026	13-02-2026	1st Lift of Tank	1.2.4	210 kg/cm2	217.78	225.19	
	F.95/56/2025						222.22		
7.2	F.95/57/2025						235.56		
	F.95/58/2025	16-01-2026	13-02-2026	1st Lift of Tank	1.2.4	210 kg/cm2	222.22	226.67	do
	F.95/59/2025						222.22		
8.1	F.95/60/2025						231.11		
	F.95/61/2025	17-01-2026	16-02-2026	1st Lift of Tank	1.2.4	210 kg/cm2	231.11	228.15	do
	F.95/62/2025						222.22		
8.2	F.95/63/2025						235.56		
	F.95/64/2025	17-01-2026	16-02-2026	1st Lift of Tank	1.2.4	210 kg/cm2	222.22	225.19	do
	F.95/65/2025						217.78		
8.3	F.95/66/2025						231.11		
	F.95/67/2025	17-01-2026	16-02-2026	1st Lift of Tank	1.2.4	210 kg/cm2	222.22	226.67	do
	F.95/68/2025						226.67		
9.1	F.95/69/2025						231.11		
	F.95/70/2025	19-01-2026	16-02-2026	1st Lift of Tank	1.2.4	210 kg/cm2	213.33	222.22	do
	F.95/71/2025						222.22		
9.2	F.95/72/2025						235.56		
	F.95/73/2025	19-01-2026	16-02-2026	1st Lift of Tank	1.2.4	210 kg/cm2	217.78	225.19	do
	F.95/74/2025						222.22		
10.1	F.95/75/2025						240.00		
	F.95/76/2025	20-01-2026	17-02-2026	1st Lift of Tank	1.2.4	210 kg/cm2	213.33	222.22	do
	F.95/77/2025						213.33		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to Irrigation tank/ spring in Sy.No. 70 Village Candepar, ward No. 2 Panchame in V.P. Curti Khandepar in Ponda Taluka.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
10.2	F.95/78/2025						226.67		No. WRD/WD XI/ SD IV/ W.F 677/ 700 /2025-26. DATED: 02-02-2026.
	F.95/79/2025	20-01-2026	17-02-2026	1st Lift of Tank	1.2.4	210 kg/cm2	226.67	226.67	
	F.95/80/2025						226.67		
11.1	F.95/81/2025						213.33		
	F.95/82/2025	21-01-2026	18-02-2026	2nd Lift of Tank	1.2.4	210 kg/cm2	231.11	223.70	do
	F.95/83/2025						226.67		
11.2	F.95/84/2025						226.67		
	F.95/85/2025	21-01-2026	18-02-2026	2nd Lift of Tank	1.2.4	210 kg/cm2	231.11	226.67	do
	F.95/86/2025						222.22		
12.1	F.95/87/2025						231.11		
	F.95/88/2025	23-01-2026	20-02-2026	2nd Lift of Tank	1.2.4	210 kg/cm2	217.78	222.22	do
	F.95/89/2025						217.78		
12.2	F.95/90/2025						226.67		
	F.95/91/2025	23-01-2026	20-02-2026	2nd Lift of Tank	1.2.4	210 kg/cm2	217.78	220.74	do
	F.95/92/2025						217.78		
13.1	F.95/93/2025						231.11		
	F.95/94/2025	24-01-2026	21-02-2026	2nd Lift of Tank	1.2.4	210 kg/cm2	222.22	223.70	do
	F.95/95/2025						217.78		
13.2	F.95/96/2025						222.22		
	F.95/97/2025	24-01-2026	21-02-2026	2nd Lift of Tank	1.2.4	210 kg/cm2	231.11	225.18	do
	F.95/98/2025						222.22		
14.1	F.95/99/2025						222.22		
	F.95/100/2025	26-01-2026	23-02-2026	3rd Lift of Tank	1.2.4	210 kg/cm2	226.67	226.67	do
	F.95/101/2025						231.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to Irrigation tank/ spring in Sy.No. 70 Village Candepar, ward No. 2 Panchame in V.P. Curti Khandepar in Ponda Taluka.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
14.2	F.95/102/2025						231.11		No. WRD/WD XI/ SD IV/ W.F 677/ 700 /2025-26. DATED: 02-02-2026.
	F.95/103/2025	26-01-2026	23-02-2026	3rd Lift of Tank	1.2.4	210 kg/cm2	231.11	226.67	
	F.95/104/2025						217.78		
15.1	F.95/105/2025						222.22		
	F.95/106/2025	27-01-2026	24-02-2026	3rd Lift of Tank	1.2.4	210 kg/cm2	226.67	225.19	do
	F.95/107/2025						226.67		
15.2	F.95/108/2025						222.22		
	F.95/109/2025	27-01-2026	24-02-2026	3rd Lift of Tank	1.2.4	210 kg/cm2	231.11	223.70	do
	F.95/110/2025						217.78		
16.1	F.95/111/2025						231.11		
	F.95/112/2025	29-01-2026	26-02-2026	3rd Lift of Tank	1.2.4	210 kg/cm2	213.33	222.22	do
	F.95/113/2025						222.22		
16.2	F.95/114/2025						226.67		
	F.95/115/2025	29-01-2026	26-02-2026	3rd Lift of Tank	1.2.4	210 kg/cm2	222.22	223.70	do
	F.95/116/2025						222.22		
17.1	F.95/117/2025						240.00		
	F.95/118/2025	31-01-2026	28-02-2026	3rd Lift of Tank	1.2.4	210 kg/cm2	213.33	222.22	do
	F.95/119/2025						213.33		
17.2	F.95/120/2025						235.56		
	F.95/121/2025	31-01-2026	28-02-2026	3rd Lift of Tank	1.2.4	210 kg/cm2	217.78	225.19	do
	F.95/122/2025						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER