

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of nallah bank LHS side at Portem in Sy.No. 45 plot No. A-148 V.P. Vaddem Curdi in Sanguem Taluka.

SAMPLE SENT BY: AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.149/06/2023						231.11		No. WRD/ SD I/ WD XII/ F.47/12/2024-25. DATED: 12-04-2024
	F.149/07/2023	23-03-2024	20-04-2024	Foundation Ch. 0.00 m to 15.00 m	1.2.4	210 kg/cm2	226.67	226.67	
	F.149/08/2023						222.22		
2	F.149/09/2023						235.56		
	F.149/10/2023	26-03-2024	23-04-2024	Foundation Ch. 15.00 m to 30.00 m	1.2.4	210 kg/cm2	217.78	225.19	do
	F.149/11/2023						222.22		
3	F.149/12/2023						235.56		
	F.149/13/2023	28-03-2024	25-04-2024	Foundation Ch. 30.00 m to 45.00 m	1.2.4	210 kg/cm2	226.67	228.15	do
	F.149/14/2023						222.22		
4	F.149/15/2023			Foundation Ch. 45.00 m to 50.00m			231.11		
	F.149/16/2023	30-03-2024	27-04-2024	inbetween Ch 0 to 45 Vertical Bend	1.2.4	210 kg/cm2	222.22	228.15	do
	F.149/17/2023			& Middle Bend			231.11		
5	F.149/18/2023						235.56		
	F.149/19/2023	1/4/2024	29-04-2024	Inbetween Ch 0 to 50 mts	1.2.4	210 kg/cm2	222.22	226.67	do
	F.149/20/2023			Vertical bends & Top bends in			222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER