

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of retaining wall opposite Silver Spring Hall Chandrawaddo in Fatorda Constituency.

SAMPLE SENT BY: AE, SD III, WD II, WRD, Fatorda - Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F. 97/11/2024						235.56		No. WRD/SD III/ WD II/ F. 77/377/2024-25. DATED: 18-03-2025.
	F. 97/12/2024	24-02-2025	24-03-2025	Foundation	1.2.4	210 kg/cm2	226.67	229.63	
	F. 97/13/2024						226.67		
1.2	F. 97/14/2024						235.56		do
	F. 97/15/2024	24-02-2025	24-03-2025	Foundation	1.2.4	210 kg/cm2	231.11	231.11	
	F. 97/16/2024						226.67		
2.1	F. 97/17/2024						226.67		do
	F. 97/18/2024	27-02-2025	27-03-2025	Super Structure	1.2.4	210 kg/cm2	235.56	228.15	
	F. 97/19/2024						222.22		
2.2	F. 97/20/2024						231.11		do
	F. 97/21/2024	27-02-2025	27-03-2025	Super Structure	1.2.4	210 kg/cm2	226.67	226.67	
	F. 97/22/2024						222.22		
3.1	F. 97/23/2024						244.44		do
	F. 97/24/2024	11/3/2025	8/4/2025	Foundation	1.2.4	210 kg/cm2	217.78	228.15	
	F. 97/25/2024						222.22		
3.2	F. 97/26/2024						235.56		do
	F. 97/27/2024	11/3/2025	8/4/2025	Foundation	1.2.4	210 kg/cm2	231.11	231.11	
	F. 97/28/2024						226.67		
4.1	F. 97/29/2024						226.67		do
	F. 97/30/2024	17-03-2025	15-04-2025	Super Structure	1.2.4	210 kg/cm2	231.11	229.63	
	F. 97/31/2024						231.11		
4.2	F. 97/32/2024						222.22		do
	F. 97/33/2024	17-03-2025	15-04-2025	Super Structure	1.2.4	210 kg/cm2	226.67	226.67	
	F. 97/34/2024						231.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of retaining wall opposite Silver Spring Hall Chandrawaddo in Fatorda Constituency.

SAMPLE SENT BY: AE, SD III, WD II, WRD, Fatorda - Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	F. 97/35/2024						240.00		No. WRD/SD III/ WD II/ F. 77/ 398 /2024-25. DATED: 28-03-2025.
	F. 97/36/2024	21-03-2025	18-04-2025	Foundation	1.2.4	210 kg/cm2	231.11	229.63	
	F. 97/37/2024						217.78		
5.2	F. 97/38/2024						231.11		
	F. 97/39/2024	21-03-2025	18-04-2025	Foundation	1.2.4	210 kg/cm2	226.67	231.11	do
	F. 97/40/2024						235.56		
6.1	F. 97/41/2024						226.67		
	F. 97/42/2024	27-03-2025	24-04-2025	Super Structure	1.2.4	210 kg/cm2	235.56	228.15	do
	F. 97/43/2024						222.22		
6.2	F. 97/44/2024						226.67		
	F. 97/45/2024	27-03-2025	24-04-2025	Super Structure	1.2.4	210 kg/cm2	226.67	229.63	do
	F. 97/46/2024						235.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER