

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Improvement and repairs to existing Irrigation tank (Talli) at Torl, in V.P. Shiroda of Ponda Taluka.

**SAMPLE SENT BY:** AE, SD IV, WD XI, WRD, Ponda- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

**28 days.**

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.131/11/2023						293.33		No. WRD/WD XI/ SD IV/ W.F 528/48/2024-25. <b>DATED: 22-04-2024.</b>
	F.131/12/2023	25-03-2024	22-04-2024	Cut off along wall	1.1.5.3	265 kg/cm2	280.00	285.92	
	F.131/13/2023						284.44		
1.2	F.131/14/2023						288.89		do
	F.131/15/2023	25-03-2024	22-04-2024	Cut off along wall	1.1.5.3	265 kg/cm2	288.89	287.41	
	F.131/16/2023						284.44		
1.3	F.131/17/2023						297.78		do
	F.131/18/2023	25-03-2024	22-04-2024	Cut off along wall	1.1.5.3	265 kg/cm2	280.00	284.45	
	F.131/19/2023						275.56		
1.4	F.131/20/2023						297.78		do
	F.131/21/2023	25-03-2024	22-04-2024	Cut off along wall	1.1.5.3	265 kg/cm2	280.00	285.93	
	F.131/22/2023						280.00		
2.1	F.131/23/2023						293.33		do
	F.131/24/2023	26-03-2024	23-04-2024	Cut off along wall	1.1.5.3	265 kg/cm2	280.00	285.92	
	F.131/25/2023						284.44		
2.2	F.131/26/2023						288.89		do
	F.131/27/2023	26-03-2024	23-04-2024	Cut off along wall	1.1.5.3	265 kg/cm2	293.33	287.41	
	F.131/28/2023						280.00		
2.3	F.131/29/2023						293.33		do
	F.131/30/2023	26-03-2024	23-04-2024	Cut off along wall	1.1.5.3	265 kg/cm2	280.00	284.44	
	F.131/31/2023						280.00		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Improvement and repairs to existing Irrigation tank (Talli) at Torl, in V.P. Shiroda of Ponda Taluka.

**SAMPLE SENT BY:** AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
3.1	F.131/32/2023						293.33		No. WRD/WD XI/ SD IV/ W.F 528/48/2024-25. <b>DATED: 22-04-2024.</b>
	F.131/33/2023	28-03-2024	25-04-2024	U/s and D/s of gate	1.1.5.3	265 kg/cm2	280.00	284.44	
	F.131/34/2023						280.00		
3.2	F.131/35/2023						280.00		
	F.131/36/2023	28-03-2024	25-04-2024	U/s and D/s of gate	1.1.5.3	265 kg/cm2	284.44	282.96	do
	F.131/37/2023						284.44		
3.3	F.131/38/2023						293.33		
	F.131/39/2023	28-03-2024	25-04-2024	U/s and D/s of gate	1.1.5.3	265 kg/cm2	284.44	285.92	do
	F.131/40/2023						280.00		
4.1	F.131/41/2023						293.33		
	F.131/42/2023	29-03-2024	26-04-2024	U/s and D/s of gate wall foundation	1.1.5.3	265 kg/cm2	275.56	284.44	do
	F.131/43/2023						284.44		
4.2	F.131/44/2023						297.78		
	F.131/45/2023	29-03-2024	26-04-2024	U/s and D/s of gate wall foundation	1.1.5.3	265 kg/cm2	275.56	284.45	do
	F.131/46/2023						280.00		
5.1	F.131/47/2023						293.33		
	F.131/48/2023	31-03-2024	28-04-2024	Wall Concrete	1.1.5.3	265 kg/cm2	288.89	285.93	do
	F.131/49/2023						275.56		
5.2	F.131/50/2023						288.89		
	F.131/51/2023	31-03-2024	28-04-2024	Wall Concrete	1.1.5.3	265 kg/cm2	280.00	281.48	do
	F.131/52/2023						275.56		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**