

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Providing RCC Canal Lining to Minor M1 Canal from Ch 2400 to 2980 mts in Cacora Village of Quepem Taluka.

**SAMPLE SENT BY:** AE, SD I, WD X, WRD, Quepem-Goa.

**NAME OF THE AGENCY :** M/s Ashko Builders, Navelim, Goa.

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
	572						271.11		No. WRD/WD X
1	573	22-11-2019	20-12-2019	7.50 cm R.C.C Canal Lining.	1.1.5.3	265 kg/cm2	271.11	269.63	/SD I/WF.10/20/
	574						266.67		2019-20/159/2019-20
	575						266.67		Dt.23/11/2019
2	576	22-11-2019	20-12-2019	7.50 cm R.C.C Canal Lining.	1.1.5.3	265 kg/cm2	275.56	269.63	do
	577						266.67		

**TECHNICAL ASSISTANT**  
(Dhananjay R. Nagvenkar)

**ASSISTANT ENGINEER**  
(Pravin C. Parsekar)