

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Retaining wall for the nallah in Sy.No. 320/1, 323/0 in V.P. Loutulim in Nuvem Constituency.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfnd- Goa.

| NAME OF THE AGENCY |              |              |              | TESTING PERIOD     |                | 07 days.               |                                |                              |   |
|--------------------|--------------|--------------|--------------|--------------------|----------------|------------------------|--------------------------------|------------------------------|---|
| REPORT NO          | SAMPLE NOS.  | CASTING DATE | TESTING DATE | LOCATION OF SAMPLE | MIX PROPORTION | REQUIRED STRENGTH      | Comp sth in Kg/cm <sup>2</sup> | Avg. Comp Kg/cm <sup>2</sup> | LETTER No / DATED   |
| 1                  | F.75/05/2021 |              |              |                    |                |                        | 115.56                         |                              | No. WRD/SD I/WD II/<br>F.Estt/722/2021-22<br><b>DATED:- 01-02-2022.</b> |
|                    | F.75/06/2021 | 25-01-2022   | 1/2/2022     | Foundation         | 1.2.4          | 100 kg/cm <sup>2</sup> | 111.11                         | 114.08                       |   |
|                    | F.75/07/2021 |              |              |                    |                |                        | 115.56                         |                              |   |
| 2                  | F.75/08/2021 |              |              |                    |                |                        | 115.56                         |                              | do  |
|                    | F.75/09/2021 | 26-01-2022   | 2/2/2022     | Foundation         | 1.2.4          | 100 kg/cm <sup>2</sup> | 120.00                         | 115.56                       |   |
|                    | F.75/10/2021 |              |              |                    |                |                        | 111.11                         |                              |   |
| 3                  | F.75/11/2021 |              |              |                    |                |                        | 115.56                         |                              | do  |
|                    | F.75/12/2021 | 27-01-2022   | 3/2/2022     | Wall               | 1.2.4          | 100 kg/cm <sup>2</sup> | 111.11                         | 112.59                       |   |
|                    | F.75/13/2021 |              |              |                    |                |                        | 111.11                         |                              |   |
| 4                  | F.75/14/2021 |              |              |                    |                |                        | 120.00                         |                              | do  |
|                    | F.75/15/2021 | 28-01-2022   | 4/2/2022     | Wall               | 1.2.4          | 100 kg/cm <sup>2</sup> | 111.11                         | 117.04                       |   |
|                    | F.75/16/2021 |              |              |                    |                |                        | 120.00                         |                              |   |
| 5                  | F.75/17/2021 |              |              |                    |                |                        | 115.56                         |                              | do  |
|                    | F.75/18/2021 | 30-01-2022   | 6/2/2022     | Wall               | 1.2.4          | 100 kg/cm <sup>2</sup> | 115.55                         | 114.07                       |   |
|                    | F.75/19/2021 |              |              |                    |                |                        | 111.11                         |                              |   |
| 6                  | F.75/20/2021 |              |              |                    |                |                        | 120.00                         |                              | do  |
|                    | F.75/21/2021 | 31-01-2022   | 7/2/2022     | Wall               | 1.2.4          | 100 kg/cm <sup>2</sup> | 111.11                         | 114.07                       |   |
|                    | F.75/22/2021 |              |              |                    |                |                        | 111.11                         |                              |   |

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**

## SD III (QC) , WRD, GOGAL, MARGAO- GOA.

**NAME OF THE WORK:** Construction of Retaining wall for the nallah in Sy.No. 320/1, 323/0 in V.P. Loutulim in Nuvem Constituency.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

07 days.

| REPORT NO | SAMPLE NOS.  | CASTING DATE | TESTING DATE | LOCATION OF SAMPLE | MIX<br>PROPOTION | REQUIRED<br>STRENGTH | Comp sth in<br>Kg/cm2 | Avg. Comp<br>Kg/cm2 | LETTER No / DATED   |
|-----------|--------------|--------------|--------------|--------------------|------------------|----------------------|-----------------------|---------------------|---|
| 1         | F.75/41/2021 |              |              |                    |                  |                      | 115.56                |                     | No. WRD/SD I/WD II/<br>F.Estt/732/2021-22<br><b>DATED:- 10-02-2022.</b> |
|           | F.75/42/2021 | 4/2/2021     | 11-02-2022   | Foundation         | 1.2.4            | 100 kg/cm2           | 111.11                | 114.08              |   |
|           | F.75/43/2021 |              |              |                    |                  |                      | 115.56                |                     |   |
| 2         | F.75/44/2021 |              |              |                    |                  |                      | 115.56                |                     | do  |
|           | F.75/45/2021 | 5/2/2022     | 12/2/2022    | Foundation         | 1.2.4            | 100 kg/cm2           | 120.00                | 115.56              |   |
|           | F.75/46/2021 |              |              |                    |                  |                      | 111.11                |                     |   |
| 3         | F.75/47/2021 |              |              |                    |                  |                      | 115.56                |                     | do  |
|           | F.75/48/2021 | 7/2/2022     | 14-02-2022   | Wall               | 1.2.4            | 100 kg/cm2           | 111.11                | 112.59              |   |
|           | F.75/49/2021 |              |              |                    |                  |                      | 111.11                |                     |   |
| 4         | F.75/50/2021 |              |              |                    |                  |                      | 120.00                |                     | do  |
|           | F.75/51/2021 | 8/2/2022     | 15-02-2022   | Wall               | 1.2.4            | 100 kg/cm2           | 111.11                | 117.04              |   |
|           | F.75/52/2021 |              |              |                    |                  |                      | 120.00                |                     |   |
| 5         | F.75/53/2021 |              |              |                    |                  |                      | 115.56                |                     | do  |
|           | F.75/54/2021 | 9/2/2022     | 16-02-2022   | Wall               | 1.2.4            | 100 kg/cm2           | 115.55                | 114.07              |   |
|           | F.75/55/2021 |              |              |                    |                  |                      | 111.11                |                     |   |

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**