

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to nallah bank at Shirwada in Sy.No. 46/4 in V.P. Shiroda in Shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.118/06/2021						115.56		No. WRD/WD XI/SD IV/
	F.118/07/2021	4/4/2022	11/4/2022	Foundation	1.2.4	100 kg/cm2	120.00	118.52	F.185/16/2022-23
	F.118/08/2021						120.00		DATED:- 11-04-2022
2	F.118/09/2021						115.56		
	F.118/10/2021	5/4/2022	12/4/2022	Foundation	1.2.4	100 kg/cm2	120.00	115.56	do
	F.118/11/2021						111.11		
3	F.118/12/2021						115.56		
	F.118/13/2021	6/4/2022	13-04-2022	Foundation	1.2.4	100 kg/cm2	124.44	117.04	do
	F.118/14/2021						111.11		
4	F.118/15/2021						120.00		
	F.118/16/2021	7/4/2022	14-04-2022	Foundation	1.2.4	100 kg/cm2	120.00	117.04	do
	F.118/17/2021						111.11		
5	F.118/18/2021						115.56		
	F.118/19/2021	8/4/2022	16-04-2022	Foundation	1.2.4	100 kg/cm2	115.55	117.04	do
	F.118/20/2021						120.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER