

NO.WRD/WDXI/SDIII/TECH/W.F.147-Oct-2024/2025-26/136

. Dated:-27/05/2025

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Development of Chimetyaband at Dapot Maxem in V.P. Loliem Polem in Canacona Taluka.

**SAMPLE SENT BY:** AE, SD I, WD XI, WRD, Canacona- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

**07 days.**

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.147/06/2024						177.78		No. WRD/WD XI/SD I/
	F.147/07/2024	1/5/2025	8/5/2025	Concreting of cut off	1.1.5.3	175 kg/cm2	186.67	182.22	F.107-3/ <b>43</b> /2025-26.
	F.147/08/2024						182.22		<b>DATED: 08-05-2025</b>
2	F.147/09/2024						191.11		
	F.147/10/2024	1/5/2025	8/5/2025	Concreting of PCC for raft foundation	1.1.5.3	175 kg/cm2	191.11	186.67	do
3	F.147/11/2024						177.78		
	F.147/12/2024						195.56		No. WRD/WD XI/SD I/
	F.147/13/2024	8/5/2025	15-05-2025	Concreting of raft foundation	1.1.5.3	175 kg/cm2	177.78	185.19	F.107-3/ <b>47</b> /2025-26.
4	F.147/14/2024						182.22		<b>DATED: 12-05-2025</b>
	F.147/15/2024						186.67		No. WRD/WD XI/SD I/
	F.147/16/2024	17-05-2025	24-05-2025	Concreting of wall II nd Lift	1.1.5.3	175 kg/cm2	186.67	183.71	F.107-3/ <b>54</b> /2025-26.
	F.147/17/2024						177.78		<b>DATED: 19-05-2025</b>

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**