

NO.WRD/WDXI/SDIII/TECH/W.F.45/2024/2025-26/ 407

. Dated:-12/03/2025

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to existing Irrigation tank (Tollem) at Paz in V.P. Shiroda of Shiroda Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F. 45/107/2024						146.67		No. WRD/WD XI/ SD IV/ W.F. 556/658/2024-25. DATED: 10-03-2025.
	F. 45/108/2024	3/3/2025	10/3/2025	Tank wall (Main) 2nd Lift	1.2.4	140 kg/cm2	155.56	148.15	
	F. 45/109/2024						142.22		
1.2	F. 45/110/2024						151.11		
	F. 45/111/2024	3/3/2025	10/3/2025	Tank wall (Main) 2nd Lift	1.2.4	140 kg/cm2	142.22	149.63	do
	F. 45/112/2024						155.56		
2.1	F. 45/113/2024						151.11		
	F. 45/114/2024	5/3/2025	12/3/2025	Tank wall (Main) 3rd Lift	1.2.4	140 kg/cm2	155.56	148.15	do
	F. 45/115/2024			Horizontal Top band			137.78		
2.2	F. 45/116/2024						146.67		
	F. 45/117/2024	5/3/2025	12/3/2025	Tank wall (Main) 3rd Lift	1.2.4	140 kg/cm2	151.11	146.67	do
	F. 45/118/2024			Horizontal Top band			142.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER