

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of box conduit for Paroda Canal from Ch.300 m to 550 m in front of Quepem Municipal Council and further from 727 mts to 847 mts and its allied works for Paroda Canal in Quepem Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
15	F.147/211/2021						288.89		No. WRD/SD I/WD II/
	F.147/212/2021	4/11/2022	11/11/2022	Raft/ Wall	M 30	255 kg/cm2	293.33	288.89	F.Estt/484/2022-23.
	F.147/213/2021						284.44		<b>DATED: 11-11-2022.</b>
16	F.147/214/2021						293.33		
	F.147/215/2021	5/11/2022	12/11/2022	Raft/ Wall	M 30	255 kg/cm2	284.44	285.92	do
	F.147/216/2021						280.00		
17	F.147/217/2021						297.78		
	F.147/218/2021	7/11/2022	14-11-2022	Raft/ Wall	M 30	255 kg/cm2	293.33	294.81	do
	F.147/219/2021						293.33		
18	F.147/220/2021						288.89		
	F.147/221/2021	8/11/2022	15-11-2022	Raft/ Wall	M 30	255 kg/cm2	293.33	287.41	do
	F.147/222/2021						280.00		
19	F.147/223/2021						288.89		
	F.147/224/2021	9/11/2022	16-11-2022	Raft/ Wall	M 30	255 kg/cm2	293.33	291.85	do
	F.147/225/2021						293.33		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of box conduit for Paroda Canal from Ch.300 m to 550 m in front of Quepem Municipal Council and further from 727 mts to 847 mts and its allied works for Paroda Canal in Quepem Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY				TESTING PERIOD		07 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
20	F.147/277/2021						284.44		No. WRD/SD I/WD II/ F.Esst/496/2022-23. <b>DATED: 18-11-2022.</b>
	F.147/278/2021	11/11/2022	18-11-2022	Raft/ Wall	M 30	255 kg/cm2	288.89	288.89	
	F.147/279/2021						293.33		
21	F.147/280/2021						297.78		do
	F.147/281/2021	12/11/2022	19-11-2022	Raft/ Wall	M 30	255 kg/cm2	288.89	290.37	
	F.147/282/2021						284.44		
22	F.147/283/2021						275.56		do
	F.147/284/2021	13-11-2022	20-11-2022	Raft/ Wall	M 30	255 kg/cm2	288.89	284.45	
	F.147/285/2021						288.89		
23	F.147/286/2021						293.33		do
	F.147/287/2021	14-11-2022	21-11-2022	Raft/ Wall	M 30	255 kg/cm2	284.44	285.92	
	F.147/288/2021						280.00		
24	F.147/289/2021						213.33		do
	F.147/290/2021	14-11-2022	21-11-2022	Bed PCC	M 20	178 kg/cm2	208.89	213.33	
	F.147/291/2021						217.78		
25	F.147/292/2021						262.22		do
	F.147/293/2021	16-11-2022	23-11-2022	Raft/ Wall	M 30	255 kg/cm2	275.56	272.59	
	F.147/294/2021						280.00		
26	F.147/295/2021						284.44		do
	F.147/296/2021	17-11-2022	24-11-2022	Raft/ Wall	M 30	255 kg/cm2	275.56	277.04	
	F.147/297/2021						271.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

## GOVERNMENT OF GOA

**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of box conduit for Paroda Canal from Ch.300 m to 550 m in front of Quepem Muncipal Council and further from 727 mts to 847 mts and its allied works for Paroda Canal in Quepem Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm <sup>2</sup>	Avg. Comp Kg/cm <sup>2</sup>	LETTER No / DATED
27	F.147/362/2021						208.89		No. WRD/SD I/WD II/
	F.147/363/2021	15-11-2022	22-11-2022	Bed PCC	M 20	178 kg/cm <sup>2</sup>	204.44	207.41	F.Esst/504/2022-23.
	F.147/364/2021						208.89		<b>DATED: 22-11-2022.</b>
28	F.147/365/2021						204.44		
	F.147/366/2021	18-11-2022	25-11-2022	Bed PCC	M 20	178 kg/cm <sup>2</sup>	213.33	208.89	do
	F.147/367/2021						208.89		
29	F.147/368/2021						284.44		
	F.147/369/2021	19-11-2022	26-11-2022	Raft/ Wall	M 30	255 kg/cm <sup>2</sup>	293.33	285.92	do
	F.147/370/2021						280.00		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**