

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of protection wall to the side bank of the Verna lake in Sy.No.131-5A and Sy.No131-6 in Village Verna in Nuvem Constituency of salcete Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

**28 days.**

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.154/11/2023						231.11		No. WRD/ SD I/ WD II/ F.Esst/56/2024-25. <b>DATED: 02-05-2024</b>
	F.154/12/2023	10/4/2024	8/5/2024	Foundation	1.2.4	210 kg/cm2	222.22	229.63	
	F.154/13/2023						235.56		
1.2	F.154/14/2023						226.67		do
	F.154/15/2023	10/4/2024	8/5/2024	Foundation	1.2.4	210 kg/cm2	231.11	231.11	
	F.154/16/2023						235.56		
2.1	F.154/17/2023						226.67		do
	F.154/18/2023	11/4/2024	9/5/2024	Coping	1.2.4	210 kg/cm2	226.67	228.15	
	F.154/19/2023						231.11		
2.2	F.154/20/2023						235.56		do
	F.154/21/2023	11/4/2024	9/5/2024	Coping	1.2.4	210 kg/cm2	217.78	226.67	
	F.154/22/2023						226.67		
3.1	F.154/23/2023						240.00		do
	F.154/24/2023	12/4/2024	10/5/2024	Foundation & Coping	1.2.4	210 kg/cm2	231.11	229.63	
	F.154/25/2023						217.78		
3.2	F.154/26/2023						231.11		do
	F.154/27/2023	12/4/2024	10/5/2024	Foundation & Coping	1.2.4	210 kg/cm2	235.56	229.63	
	F.154/28/2023						222.22		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of protection wall to the side bank of the Verna lake in Sy.No.131-5A and Sy.No131-6 in Village Verna in Nuvem Constituency of salcete Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

**28 days.**

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
3.3	F.154/29/2023						226.67		No. WRD/ SD I/ WD II/ F.Esstt/56/2024-25. <b>DATED: 02-05-2024</b>
	F.154/30/2023	12/4/2024	10/5/2024	Foundation & Coping	1.2.4	210 kg/cm2	231.11	231.11	
	F.154/31/2023						235.56		
3.4	F.154/32/2023						235.56		
	F.154/33/2023	12/4/2024	10/5/2024	Foundation & Coping	1.2.4	210 kg/cm2	217.78	228.15	do
	F.154/34/2023						231.11		
4.1	F.154/35/2023						222.22		
	F.154/36/2023	13-04-2024	13-05-2024	Coping	1.2.4	210 kg/cm2	226.67	226.67	do
	F.154/37/2023						231.11		
4.2	F.154/38/2023						226.67		
	F.154/39/2023	13-04-2024	13-05-2024	Coping	1.2.4	210 kg/cm2	217.78	222.22	do
	F.154/40/2023						222.22		
5.1	F.154/41/2023						231.11		
	F.154/42/2023	15-04-2024	13-05-2024	Coping	1.2.4	210 kg/cm2	231.11	229.63	do
	F.154/43/2023						226.67		
5.2	F.154/44/2023						235.56		
	F.154/45/2023	15-04-2024	13-05-2024	Coping	1.2.4	210 kg/cm2	217.78	226.67	do
	F.154/46/2023						226.67		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**