

NO: WRD /WD XI / SD III/ TECH/W.F. 01-2022/76 / 2022-23

Dated:17/12/2022

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Providing flood control measures and stabilization of banks at Kansurlim, Xeldem Village of Quepem Taluka in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.01/11/2022						244.44		No. WRD/WD XII/SD V/ F.70/175/2022-23. DATED: 23-11-2022
	F.01/12/2022	5/11/2022	5/12/2022	Foundation	1.2.4	210 kg/cm2	240.00	241.48	
	F.01/13/2022						240.00		
1.2	F.01/14/2022						248.89		do
	F.01/15/2022	5/11/2022	5/12/2022	Foundation	1.2.4	210 kg/cm2	240.00	242.96	
	F.01/16/2022						240.00		
2.1	F.01/17/2022						235.56		do
	F.01/18/2022	7/11/2022	5/12/2022	Foundation	1.2.4	210 kg/cm2	240.00	235.56	
	F.01/19/2022						231.11		
2.2	F.01/20/2022						235.56		do
	F.01/21/2022	7/11/2022	5/12/2022	Foundation	1.2.4	210 kg/cm2	226.67	234.08	
	F.01/22/2022						240.00		
3.1	F.01/23/2022						226.67		do
	F.01/24/2022	8/11/2022	6/12/2022	Foundation	1.2.4	210 kg/cm2	235.56	235.56	
	F.01/25/2022						244.44		
3.2	F.01/26/2022						231.11		do
	F.01/27/2022	8/11/2022	6/12/2022	Foundation	1.2.4	210 kg/cm2	240.00	234.07	
	F.01/28/2022						231.11		
4.1	F.01/29/2022						235.56		do
	F.01/30/2022	9/11/2022	7/12/2022	Super Structure	1.2.4	210 kg/cm2	217.78	228.15	
	F.01/31/2022						231.11		
4.2	F.01/32/2022						222.22		do
	F.01/33/2022	9/11/2022	7/12/2022	Super Structure	1.2.4	210 kg/cm2	231.11	228.15	
	F.01/34/2022						231.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Providing flood control measures and stabilization of banks at Kansurlim, Xeldem Village of Quepem Taluka in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	F.01/35/2022								No. WRD/WD XII/SD V/ F.70/175/2022-23. DATED: 23-11-2022
	F.01/36/2022	10/11/2022	8/12/2022	Super Structure	1.2.4	210 kg/cm2	226.67	231.12	
	F.01/37/2022						235.56		
5.2	F.01/38/2022						235.56		
	F.01/39/2022	10/11/2022	8/12/2022	Super Structure	1.2.4	210 kg/cm2	231.11	231.11	do
	F.01/40/2022						226.67		
6.1	F.01/41/2022						240.00		
	F.01/42/2022	11/11/2022	9/12/2022	Super Structure	1.2.4	210 kg/cm2	213.33	229.63	do
	F.01/43/2022						235.56		
6.2	F.01/44/2022						226.67		
	F.01/45/2022	11/11/2022	9/12/2022	Super Structure	1.2.4	210 kg/cm2	222.22	226.67	do
	F.01/46/2022						231.11		
7.1	F.01/47/2022						248.89		
	F.01/48/2022	12/11/2022	12/12/2022	Super Structure	1.2.4	210 kg/cm2	231.11	238.19	do
	F.01/49/2022						234.56		
7.2	F.01/50/2022						235.56		
	F.01/51/2022	12/11/2022	12/12/2022	Super Structure	1.2.4	210 kg/cm2	240.00	238.52	do
	F.01/52/2022						240.00		
8.1	F.01/53/2022						226.67		
	F.01/54/2022	14-11-2022	12/12/2022	Super Structure	1.2.4	210 kg/cm2	208.89	222.22	do
	F.01/55/2022						231.11		
8.2	F.01/56/2022						213.33		
	F.01/57/2022	14-11-2022	12/12/2022	Super Structure	1.2.4	210 kg/cm2	226.67	223.70	do
	F.01/58/2022						231.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Providing flood control measures and stabilization of banks at Kansurlim, Xeldem Village of Quepem Taluka in Curchorem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
9.1	F.01/59/2022						235.56		No. WRD/WD XII/SD V/ F.70/ 174 /2022-23. DATED: 23-11-2022
	F.01/60/2022	17-11-2022	15-12-2022	R.R.Masonry Foundation	1.2.4	210 kg/cm2	235.56	234.08	
	F.01/61/2022						231.11		
9.2	F.01/62/2022						240.00		
	F.01/63/2022	17-11-2022	15-12-2022	R.R.Masonry Foundation	1.2.4	210 kg/cm2	231.11	234.07	do
	F.01/64/2022						231.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER