

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of nallah side protection wall from old age home to Martonio Enclaves at Vanxem in V.P. Loutolim in Nuvem Constituency.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfnd- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.69/04/2021						115.56		No. WRD/SD I/WD II/
	F.69/05/2021	25-01-2022	1/2/2022	Foundation	1.2.4	100 kg/cm2	120.00	118.52	F. Estt/719/2021-22
	F.69/06/2021						120.00		<b>DATED:- 01-02-2022</b>
2	F.69/07/2021						115.56		
	F.69/08/2021	26-01-2022	2/2/2022	Foundation	1.2.4	100 kg/cm2	120.00	115.56	do
	F.69/09/2021						111.11		
3	F.69/10/2021						115.56		
	F.69/11/2021	27-01-2022	3/2/2022	Pillar	1.2.4	100 kg/cm2	124.44	117.04	do
	F.69/12/2021						111.11		
4	F.69/13/2021						120.00		
	F.69/14/2021	29-01-2022	5/2/2022	Band	1.2.4	100 kg/cm2	120.00	117.04	do
	F.69/15/2021						111.11		
5	F.69/16/2021						115.56		
	F.69/17/2021	31-01-2022	7/2/2022	Band	1.2.4	100 kg/cm2	115.55	117.04	do
	F.69/18/2021						120.00		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**