

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Diversion bund and Providing PCC canal at Satarkarwada Curpem in Sanguem Taluka.

**SAMPLE SENT BY:** AE, SD I, WD XII, WRD, Pajimol- Sanguem- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.73/05/2021						115.56		No. WRD/ SD I/ WD XII/
	F.73/06/2021	10/1/2022	17-01-2022	Retaining wallabove Ch. 0 m to 15 m	1.2.4	100 kg/cm2	120.00	118.52	F.47/285/2021-22
	F.73/07/2021						120.00		<b>DATED:- 12-01-2022</b>
2	F.73/08/2021						160.00		
	F.73/09/2021	11/1/2022	18-01-2022	Canal Bed Ch 15 m to 30 m	1.1.5.3	135 kg/cm2	160.00	160.00	do
	F.73/10/2021						160.00		
3	F.73/11/2021						155.56		
	F.73/12/2021	12/1/2022	19-01-2022	Canal wall Ch 30 m to 45 m	1.1.5.3	135 kg/cm2	155.56	157.04	do
	F.73/13/2021						160.00		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**