

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Urgent repairs to the existing bandhara situated at Condi of Quepem Taluka in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
1.1	F.85/06/2021						115.56		No. WRD/WD XII/ SD V/ F.15/177/2021-22 DATED:-15-02-2022
	F.85/07/2021	9/2/2022	16-02-2022	In front of wall & Foundation	1.2.4	100 kg/cm ²	120.00	118.52	
	F.85/08/2021						120.00		
1.2	F.85/09/2021						115.56		
	F.85/10/2021	9/2/2022	16-02-2022	In front of wall & Foundation	1.2.4	100 kg/cm ²	120.00	115.56	do
	F.85/11/2021						111.11		
2	F.85/12/2021						115.56		
	F.85/13/2021	10/2/2022	17-02-2022	Back & Infront of Wall	1.2.4	100 kg/cm ²	124.44	117.04	do
	F.85/14/2021						111.11		
3	F.85/15/2021						120.00		
	F.85/16/2021	11/2/2022	18-02-2022	Side wall & back Wall	1.2.4	100 kg/cm ²	120.00	117.04	do
	F.85/17/2021						111.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER