

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Providing RCC Canal Lining to Minor M1 Canal from Ch 2400 to 2980 mts in Cacora Village of Quepem Taluka.

SAMPLE SENT BY: AE, SD I, WD X, WRD, Quepem-Goa.

NAME OF THE AGENCY : M/s Ashko Builders, Navelim, Goa.

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
	82						84.00		No. WRD/WD X
1	83	06-11-2019	13-11-2019	50mm PCC below RCC Canal lining.	1.3.6	70 kg/cm2	80.00	81.33	/SD I/F.10/142/
	84						80.00		2019-20
	85						84.44		Dt.11/11/2019
2	86	07-11-2019	14-11-2019	50mm PCC below RCC Canal lining.	1.3.6	70 kg/cm2	84.44	84.44	do
	87						84.44		
	88						84.44		
3	89	08-11-2019	15-11-2019	50mm PCC below RCC Canal lining.	1.3.6	70 kg/cm2	88.89	85.92	do
	90						84.44		

TECHNICAL ASSISTANT
(Dhananjay R. Nagvenkar)

ASSISTANT ENGINEER
(Pravin C. Parsekar)

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Providing RCC Canal Lining to Minor M1 Canal from Ch 2400 to 2980 mts in Cacora Village of Quepem Taluka.

SAMPLE SENT BY: AE, SD I, WD X, WRD, Quepem-Goa.

NAME OF THE AGENCY : M/s Ashko Builders, Navelim, Goa.

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
	271						84.44		No. WRD/WD X
1	272	09-11-2019	16-11-2019	50mm PCC below RCC Canal lining.	1.3.6	70 kg/cm2	84.44	85.92	/SD I/F.10/144/
	273						88.89		2019-20
	274						80.00		Dt.13/11/2019
2	275	10-11-2019	17-11-2019	50mm PCC below RCC Canal lining.	1.3.6	70 kg/cm2	80.00	81.48	do
	276						84.44		
	277						84.44		
3	278	11-11-2019	18-11-2019	50mm PCC below RCC Canal lining.	1.3.6	70 kg/cm2	80.00	81.48	do
	279						80.00		

TECHNICAL ASSISTANT
(Dhananjay R. Nagvenkar)

ASSISTANT ENGINEER
(Pravin C. Parsekar)