

NO.WRD/WDXI/SDIII/TECH/W.F.25/2022/2022-23/80

. Dated:-24/12/2022

GOVERNMENT OF GOA  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Improvement to nallah bank in Sy.No. 68/1 A at Adcolna V.P. Bhoma Adcolna in Priol Constituency.

**SAMPLE SENT BY:** AE, SD IV, WD XI, WRD, Ponda- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm <sup>2</sup>	Avg. Comp Kg/cm <sup>2</sup>	LETTER No / DATED
1	F.25/05/2022						151.11		No. WRD/WD XI/SD IV/ F.CF/415/2022-23. <b>DATED: 21-12-2022.</b>
	F.25/06/2022	15-12-2022	22-12-2022	For Foundation	1.2.4	140 kg/cm <sup>2</sup>	146.67	149.63	
	F.25/07/2022						151.11		
2	F.25/08/2022						160.00		
	F.25/09/2022	16-12-2022	23-12-2022	For Foundation	1.2.4	140 kg/cm <sup>2</sup>	155.56	155.56	do
	F.25/10/2022						151.11		
3	F.25/11/2022						155.56		
	F.25/12/2022	17-12-2022	24-12-2022	For Foundation	1.2.4	140 kg/cm <sup>2</sup>	155.56	154.08	do
	F.25/13/2022						151.11		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**