

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of 12 Nos RCC shallow wells in Nuvem Constituency.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.62/06/2023						293.33		No. 343/ SD III/ WD III/ WRD/24-25/27. DATED: 18-04-2024
	F.62/07/2023	5/4/2024	3/5/2024	Wells steining 3 wells	1.1.5.3	265 kg/cm2	280.00	285.92	
	F.62/08/2023						284.44		
1.2	F.62/09/2023						288.89		do
	F.62/10/2023	5/4/2024	3/5/2024	Wells steining 3 wells	1.1.5.3	265 kg/cm2	288.89	287.41	
	F.62/11/2023						284.44		
2.1	F.62/12/2023						297.78		do
	F.62/13/2023	11/4/2024	9/5/2024	RCC Rings (7 Rings) 1st Well	1.1.5.3	265 kg/cm2	280.00	284.45	
	F.62/14/2023						275.56		
2.2	F.62/15/2023						293.33		do
	F.62/16/2023	11/4/2024	9/5/2024	RCC Rings (7 Rings) 1st Well	1.1.5.3	265 kg/cm2	280.00	284.44	
	F.62/17/2023						280.00		
3.1	F.62/18/2023						297.78		do
	F.62/19/2023	16-04-2024	14-05-2024	RCC Rings (7 Rings) 2nd Well	1.1.5.3	265 kg/cm2	280.00	287.31	
	F.62/20/2023						284.14		
3.2	F.62/21/2023						293.33		do
	F.62/22/2023	16-04-2024	14-05-2024	RCC Rings (7 Rings) 2nd Well	1.1.5.3	265 kg/cm2	293.33	290.37	
	F.62/23/2023						284.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Construction of 12 Nos RCC shallow wells in Nuvem Constituency.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.62/24/2023						293.33		No. 343/ SD III/ WD III/ WRD/24-25/49. DATED: 16-05-2024
	F.62/25/2023	20-04-2024	18-05-2024	Well Rings to 1 & 2 (7 & 8 rings)+	1.1.5.3	265 kg/cm2	280.00	284.44	
	F.62/26/2023			wells steining for well 3, 4, 5, 6.			280.00		
1.2	F.62/27/2023						280.00		
	F.62/28/2023	20-04-2024	18-05-2024	Well Rings to 1 & 2 (7 & 8 rings)+	1.1.5.3	265 kg/cm2	284.44	282.96	do
	F.62/29/2023			wells steining for well 3, 4, 5, 6.			284.44		
2.1	F.62/30/2023						293.33		
	F.62/31/2023	24-04-2024	22-05-2024	Well rings for 3, 4 (7 & 8 rings)	1.1.5.3	265 kg/cm2	284.44	285.92	do
	F.62/32/2023						280.00		
2.2	F.62/33/2023						293.33		
	F.62/34/2023	24-04-2024	22-05-2024	Well rings for 3, 4 (7 & 8 rings)	1.1.5.3	265 kg/cm2	275.56	284.44	do
	F.62/35/2023						284.44		
3.1	F.62/36/2023						297.78		
	F.62/37/2023	30-04-2024	28-05-2024	Well rings for well 5 & 6 + wells	1.1.5.3	265 kg/cm2	275.56	284.45	do
	F.62/38/2023			Stening for 7, 8, 9, 10, 11, 12			280.00		
3.2	F.62/39/2023						293.33		
	F.62/40/2023	30-04-2024	28-05-2024	Well rings for well 5 & 6 + wells	1.1.5.3	265 kg/cm2	288.89	285.93	do
	F.62/41/2023			Stening for 7, 8, 9, 10, 11, 12			275.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of 12 Nos RCC shallow wells in Nuvem Constituency.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
4.1	F.62/42/2023						288.89		No. 343/ SD III/ WD III/ WRD/24-25/49. DATED: 16-05-2024
	F.62/43/2023	7/5/2024	4/6/2024	Wells Rings for 7, 8 (15 + 16 nos) rings	1.1.5.3	265 kg/cm2	275.56	282.96	
	F.62/44/2023						284.44		
4.2	F.62/45/2023						288.89		
	F.62/46/2023	7/5/2024	4/6/2024	Wells Rings for 7, 8 (15 + 16 nos) rings	1.1.5.3	265 kg/cm2	280.00	281.48	do
	F.62/47/2023						275.56		
5.1	F.62/48/2023						293.33		
	F.62/49/2023	15-05-2024	12/6/2024	Well Ring for 9 (17 rings)	1.1.5.3	265 kg/cm2	275.56	282.96	do
	F.62/50/2023						280.00		
5.2	F.62/51/2023						293.33		
	F.62/52/2023	15-05-2024	12/6/2024	Well Ring for 9 (17 rings)	1.1.5.3	265 kg/cm2	284.44	285.92	do
	F.62/53/2023						280.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

NO.WRD/WDXI/SDIII/TECH/W.F.62/2023/2024-25/120
GOVERNMENT OF GOA

. Dated:-02/07/24

SD III (QC), WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of 12 Nos RCC shallow wells in Nuvem Constituency.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
6.1	F.62/54/2023						288.89		No. 343/ SD III/ WD III/ WRD/24-25/80. DATED: 05-06-2024
	F.62/55/2023	22-05-2024	19-06-2024	Wells Streining 10 wells	1.1.5.3	265 kg/cm2	280.00	284.44	
	F.62/56/2023						284.44		
6.2	F.62/57/2023						293.33		
	F.62/58/2023	22-05-2024	19-06-2024	Wells Streining 10 wells	1.1.5.3	265 kg/cm2	280.00	285.92	do
	F.62/59/2023						284.44		
7.1	F.62/60/2023						297.78		
	F.62/61/2023	28-05-2024	25-06-2024	RCC Rings (8 Rings) 11 st well	1.1.5.3	265 kg/cm2	275.56	281.48	do
	F.62/62/2023						271.11		
7.2	F.62/63/2023						297.78		
	F.62/64/2023	28-05-2024	25-06-2024	RCC Rings (8 Rings) 11 st well	1.1.5.3	265 kg/cm2	266.67	280.00	do
	F.62/65/2023						275.56		
8.1	F.62/66/2023						289.98		
	F.62/67/2023	4/6/2024	2/7/2024	RCC Rings (9 Rings) 12 th well	1.1.5.3	265 kg/cm2	284.44	283.33	do
	F.62/68/2023						275.56		
8.2	F.62/69/2023						293.33		
	F.62/70/2023	4/6/2024	2/7/2024	RCC Rings (9 Rings) 12 th well	1.1.5.3	265 kg/cm2	280.00	280.00	do
	F.62/71/2023						266.67		

JUNIOR ENGINEER.

ASSISTANT ENGINEER