

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Open Type Bandhara near Vodli Handi and Improvement of the nallah and Dakti Handi in Sy.No. 96/8, 97/19 in V.P. Nagoa in Nuvem Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
1	F.13/05/2022						231.11		No. WRD/SD I/WD II/ F.Esst/536/2022-23. DATED: 08-12-2022.
	F.13/06/2022	15-11-2022	13-12-2022	U/s & D/s cut off	1.2.4	210 kg/cm ²	226.67	229.63	
	F.13/07/2022						231.11		
2.1	F.13/08/2022						226.67		
	F.13/09/2022	16-11-2022	14-12-2022	U/s apron & D/s Apron 1st Step	1.2.4	210 kg/cm ²	231.11	226.67	do
	F.13/10/2022						222.22		
2.2	F.13/11/2022						226.67		
	F.13/12/2022	16-11-2022	14-12-2022	U/s apron & D/s Apron 1st Step	1.2.4	210 kg/cm ²	226.67	228.15	do
	F.13/13/2022						231.11		
2.3	F.13/14/2022						231.11		
	F.13/09/2022	16-11-2022	14-12-2022	U/s apron & D/s Apron 1st Step	1.2.4	210 kg/cm ²	226.67	229.63	do
	F.13/10/2022						231.11		
3.1	F.13/11/2022						235.56		
	F.13/12/2022	17-11-2022	15-12-2022	D/s apron 2nd & 3rd Step	1.2.4	210 kg/cm ²	240.00	237.04	do
	F.13/13/2022						235.56		
3.2	F.13/14/2022						244.44		
	F.13/15/2022	17-11-2022	15-12-2022	D/s apron 2nd & 3rd Step	1.2.4	210 kg/cm ²	240.00	240.00	do
	F.13/16/2022						235.56		
4.1	F.13/17/2022						231.11		
	F.13/18/2022	19-11-2022	17-12-2022	Abutment Foundation/ Key Wall	1.2.4	210 kg/cm ²	226.67	232.59	do
	F.13/19/2022						240.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Open Type Bandhara near Vodli Handi and Improvement of the nallah and Dakti Handi in Sy.No. 96/8, 97/19 in V.P. Nagoa in Nuvem Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	TARGET STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
4.2	F.13/20/2022						240.00		No. WRD/SD I/WD II/ F.Esst/536/2022-23. DATED: 08-12-2022.
	F.13/21/2022	19-11-2022	17-12-2022	Abutment Foundation/ Key Wall	1.2.4	210 kg/cm ²	235.56	235.56	
	F.13/22/2022						231.11		
4.3	F.13/23/2022						235.56		do
	F.13/24/2022	19-11-2022	17-12-2022	Abutment Foundation/ Key Wall	1.2.4	210 kg/cm ²	235.56	234.08	
	F.13/25/2022						231.11		
4.4	F.13/26/2022						235.56		do
	F.13/27/2022	19-11-2022	17-12-2022	Abutment Foundation/ Key Wall	1.2.4	210 kg/cm ²	231.11	232.59	
	F.13/28/2022						231.11		
5.1	F.13/29/2022						226.67		do
	F.13/30/2022	21-11-2022	20-12-2022	Abutment Foundation/ Pier cut off	1.2.4	210 kg/cm ²	217.78	225.19	
	F.13/31/2022						231.11		
5.2	F.13/32/2022						226.67		do
	F.13/33/2022	21-11-2022	20-12-2022	Abutment Foundation/ Pier cut off	1.2.4	210 kg/cm ²	222.22	223.70	
	F.13/34/2022						222.22		
6.1	F.13/35/2022						222.22		do
	F.13/36/2022	22-11-2022	20-12-2022	Abutment Wall	1.2.4	210 kg/cm ²	226.67	222.22	
	F.13/37/2022						217.78		
6.2	F.13/38/2022						226.67		do
	F.13/39/2022	22-11-2022	20-12-2022	Abutment Wall	1.2.4	210 kg/cm ²	213.33	219.26	
	F.13/40/2022						217.78		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Open Type Bandhara near Vodli Handi and Improvement of the nallah and Dakti Handi in Sy.No. 96/8, 97/19 in V.P. Nagoa in Nuvem Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
6.3	F.13/41/2022						226.67		No. WRD/SD I/WD II/ F.Esst/536/2022-23. DATED: 08-12-2022.
	F.13/42/2022	22-11-2022	20-12-2022	Abutment Wall	1.2.4	210 kg/cm2	217.78	222.22	
	F.13/43/2022						222.22		
7.1	F.13/44/2022						231.11		
	F.13/45/2022	24-11-2022	22-12-2022	Abutment Foundation/ Key Wall	1.2.4	210 kg/cm2	226.67	226.67	do
	F.13/46/2022						222.22		
7.2	F.13/47/2022						235.56		
	F.13/48/2022	24-11-2022	22-12-2022	Abutment Foundation/ Key Wall	1.2.4	210 kg/cm2	226.67	228.15	do
	F.13/49/2022						222.22		
7.3	F.13/50/2022						226.67		
	F.13/51/2022	24-11-2022	22-12-2022	Abutment Foundation/ Key Wall	1.2.4	210 kg/cm2	213.33	223.70	do
	F.13/52/2022						231.11		
8.1	F.13/53/2022						235.56		
	F.13/54/2022	26-11-2022	24-12-2022	Retaining Wall	1.2.4	210 kg/cm2	226.67	235.56	do
	F.13/55/2022						244.44		
8.2	F.13/56/2022						235.56		
	F.13/57/2022	26-11-2022	24-12-2022	Retaining Wall	1.2.4	210 kg/cm2	231.11	229.63	do
	F.13/58/2022						222.22		
8.3	F.13/59/2022						231.11		
	F.13/60/2022	26-11-2022	24-12-2022	Retaining Wall	1.2.4	210 kg/cm2	222.22	228.15	do
	F.13/61/2022						231.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Open Type Bandhara near Vodli Handi and Improvement of the nallah and Dakti Handi in Sy.No. 96/8, 97/19 in V.P. Nagoa in Nuvem Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
9.1	F.13/62/2022						297.78		No. WRD/SD I/WD II/
	F.13/63/2022	28-11-2022	26-12-2022	Piers/ Culver Slab	1.1.5.3	265 kg/cm2	302.22	299.26	F.Estt/ 536 /2022-23.
	F.13/64/2022						297.78		DATED: 08-12-2022.
9.2	F.13/65/2022						302.22		
	F.13/66/2022	28-11-2022	26-12-2022	Piers/ Culver Slab	1.1.5.3	265 kg/cm2	288.89	296.30	do
	F.13/67/2022						297.78		
9.3	F.13/68/2022						302.22		
	F.13/69/2022	28-11-2022	26-12-2022	Piers/ Culver Slab	1.1.5.3	265 kg/cm2	293.33	297.78	do
	F.13/70/2022						297.78		

JUNIOR ENGINEER.

ASSISTANT ENGINEER