

NO.WRD/WDXI/SDIII/TECH/W.F.11/2022/2022-23/87

. Dated:-27/12/22

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of culvert across D2 Distribution Canal of Salaulim Irrigation Project in Survey no. 168/1 in Village Sao Jose De Areal of Salcete Taluka (2nd call).

SAMPLE SENT BY: AE, SD II, WD XII, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.11/05/2022						146.67		No. WRD/WD XII/SD II/ F.61/301/2022-23. DATED: 21-12-2022.
	F.11/06/2022	15-12-2022	22-12-2022	1st Lift	1.2.4	140 kg/cm2	146.67	151.11	
	F.11/07/2022						160.00		
2	F.11/08/2022						155.56		do
	F.11/09/2022	17-12-2022	24-12-2022	2nd Lift	1.2.4	140 kg/cm2	155.56	154.08	
	F.11/10/2022						151.11		
3	F.11/11/2022						186.67		do
	F.11/12/2022	20-12-2022	27-12-2022	Slab	1.1.5.3	175 kg/cm2	195.56	188.15	
	F.11/13/2022						182.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER