

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to nallah near Shri. Betal Temple at Dassolwada V.P. Cundaim of Marcaim Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.19/06/2022						222.22		No.WRD/WDXI/SD IV/ F.CF/402/2022-23. DATED:- 13-12-2022
	F.19/07/2022	1/12/2022	29-12-2022	Foundation	1.2.4	210 kg/cm2	217.78	220.74	
	F.19/08/2022						222.22		
2.1	F.19/09/2022						226.67		
	F.19/10/2022	2/12/2022	30-12-2022	Foundation	1.2.4	210 kg/cm2	217.78	225.19	do
	F.19/11/2022						231.11		
2.2	F.19/12/2022						226.67		
	F.19/13/2022	2/12/2022	30-12-2022	Foundation	1.2.4	210 kg/cm2	226.67	226.67	do
	F.19/14/2022						226.67		
3.1	F.19/15/2022						235.56		
	F.19/16/2022	5/12/2022	2/1/2023	Foundation	1.2.4	210 kg/cm2	240.00	235.56	do
	F.19/17/2022						231.11		
3.2	F.19/18/2022						235.56		
	F.19/19/2022	5/12/2022	2/1/2023	Foundation	1.2.4	210 kg/cm2	235.56	234.08	do
	F.19/20/2022						231.11		
4.1	F.19/21/2022						222.22		
	F.19/22/2022	6/12/2022	3/1/2023	1st Lift	1.2.4	210 kg/cm2	231.11	226.67	do
	F.19/23/2022						226.67		
4.2	F.19/24/2022						231.11		
	F.19/25/2022	6/12/2022	3/1/2023	1st Lift	1.2.4	210 kg/cm2	226.67	228.15	do
	F.19/26/2022						226.67		
5.1	F.19/27/2022						217.78		
	F.19/28/2022	7/12/2022	4/1/2023	1st Lift	1.2.4	210 kg/cm2	222.22	217.78	do
	F.19/29/2022						213.33		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Improvement to nallah near Shri. Betal Temple at Dassolwada V.P. Cundaim of Marcaim Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.2	F.19/30/2022						217.78		No.WRD/WDXI/SD IV/ F.CF/402/2022-23. DATED:- 13-12-2022
	F.19/31/2022	7/12/2022	4/1/2023	1st Lift	1.2.4	210 kg/cm2	217.78	216.30	
	F.19/32/2022						213.33		
6.1	F.19/33/2022						226.67		
	F.19/34/2022	8/12/2022	5/1/2023	1st Lift	1.2.4	210 kg/cm2	235.56	228.15	do
	F.19/35/2022						222.22		
6.2	F.19/36/2022						231.11		
	F.19/37/2022	8/12/2022	5/1/2023	1st Lift	1.2.4	210 kg/cm2	226.67	228.15	do
	F.19/38/2022						226.67		
7.1	F.19/39/2022						240.00		
	F.19/40/2022	9/12/2022	6/1/2023	2nd Lift	1.2.4	210 kg/cm2	231.11	234.07	do
	F.19/41/2022						231.11		
7.2	F.19/42/2022						235.56		
	F.19/43/2022	9/12/2022	6/1/2023	2nd Lift	1.2.4	210 kg/cm2	231.11	234.08	do
	F.19/44/2022						235.56		
8.1	F.19/45/2022						222.22		
	F.19/46/2022	10/12/2022	7/1/2023	2nd Lift	1.2.4	210 kg/cm2	222.22	222.22	do
	F.19/47/2022						222.22		
8.2	F.19/49/2022						226.67		
	F.19/50/2022	10/12/2022	7/1/2023	2nd Lift	1.2.4	210 kg/cm2	222.22	223.70	do
	F.19/51/2022						222.22		
9.1	F.19/52/2022						226.67		
	F.19/53/2022	12/12/2022	9/1/2023	3rd Lift	1.2.4	210 kg/cm2	213.33	220.74	do
	F.19/54/2022						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to nallah near Shri. Betal Temple at Dassolwada V.P. Cundaim of Marcaim Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
9.2	F.19/55/2022						222.22		No.WRD/WDXI/SD IV/
	F.19/56/2022	12/12/2022	9/1/2023	3rd Lift	1.2.4	210 kg/cm2	217.78	222.22	F.CF/402/2022-23.
	F.19/57/2022						226.67		DATED:- 13-12-2022
9.3	F.19/58/2022						222.22		
	F.19/59/2022	12/12/2022	9/1/2023	3rd Lift	1.2.4	210 kg/cm2	217.78	220.74	do
	F.19/60/2022						222.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER