

NO.WRD/WDXI/SDIII/TECH/W.F.25/2022/2022-23/97

. Dated:-16/01/2023

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement to nallah bank in Sy.No. 68/1A at Adcolna V.P. Bhoma Adcolna in Priol Constituency.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.25/14/2022						222.22		No. WRD/WD XI/SD IV/
	F.25/15/2022	15-12-2022	12/1/2023	For Foundation	1.2.4	210 kg/cm2	226.67	222.22	F.CF/415/2022-23.
	F.25/16/2022						217.78		DATED: 21-12-2022.
2	F.25/17/2022						231.11		
	F.25/18/2022	16-12-2022	13-01-2023	For Foundation	1.2.4	210 kg/cm2	231.11	229.63	do
	F.25/19/2022						226.67		
3	F.25/20/2022						235.56		
	F.25/21/2022	17-12-2022	14-01-2023	For Foundation	1.2.4	210 kg/cm2	226.67	231.11	do
	F.25/22/2022						231.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER