

NO.WRD/WDXI/SDIII/TECH/W.F.11/2022/2022-23/98

. Dated:-11/01/2022

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of culvert across D2 Distribution Canal of Salaulim Irrigation Project in Survey no. 168/1 in Village Sao Jose De Areal of Salcete Taluka (2nd call).

SAMPLE SENT BY: AE, SD II, WD XII, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	TARGET STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.11/14/2022						222.22		No. WRD/WD XII/SD II/ F.61/301/2022-23. DATED: 21-12-2022.
	F.11/15/2022	15-12-2022	12/1/2023	1st Lift	1.2.4	210 kg/cm2	226.67	223.70	
	F.11/16/2022						222.22		
2	F.11/17/2022						226.67		do
	F.11/18/2022	17-12-2022	14-01-2023	2nd Lift	1.2.4	210 kg/cm2	235.56	228.15	
	F.11/19/2022						222.22		
3	F.11/20/2022						293.33		do
	F.11/21/2022	20-12-2022	17-01-2023	Slab	1.1.5.3	265 kg/cm2	288.89	290.37	
	F.11/22/2022						288.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER