

NO: WRD /WD XI / SD III/ TECH/W.F. 131-2021/9-A / 2022-23

Dated:

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of nallah near VPHK Society behind Good Shepherd hotel at Rawanfond Margao- Goa.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogol- Margao- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
1	F.131/89/2021						240.00		No.304/SD III/ WD III/
	F.131/90/2021	11/7/2022	8/8/2022	Foundation block Ch. 110 to 121 m	1.2.4	210 kg/cm ²	231.11	237.04	WRD/ 2022-23/156.
	F.131/91/2021						240.00		DATED:- 18-07-2022.
2	F.131/92/2021						240.00		
	F.131/93/2021	13-07-2022	10/8/2022	Above Foundation Ch. 110 to 121 m	1.2.4	210 kg/cm ²	235.56	235.56	do
	F.131/94/2021						231.11		
3.1	F.131/95/2021						235.56		
	F.131/96/2021	13-07-2022	10/8/2022	2nd lift Ch. 0 to 55 mt	1.2.4	210 kg/cm ²	235.56	237.04	do
	F.131/97/2021						240.00		
3.2	F.131/98/2021						235.56		
	F.131/99/2021	13-07-2022	10/8/2022	2nd lift Ch. 0 to 55 mt	1.2.4	210 kg/cm ²	231.11	238.52	do
	F.131/100/2021						248.89		
4.1	F.131/101/2021						235.56		
	F.131/102/2021	16-07-2022	13-08-2022	2nd lift Ch. 55 to 110 mt	1.2.4	210 kg/cm ²	235.56	235.56	do
	F.131/103/2021						235.56		
4.2	F.131/104/2021						240.00		
	F.131/105/2021	16-07-2022	13-08-2022	2nd lift Ch. 55 to 110 mt	1.2.4	210 kg/cm ²	231.11	237.04	do
	F.131/106/2021						240.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER