

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Development of Ramp at Bandreshwar Temple at Guddem at Village Siolim in Siolim Constituency.

**SAMPLE SENT BY:** AE, SD I, WD I, WRD, Porvorim, Goa.

**NAME OF THE AGENCY :**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
	1799						226.67		No. MI/WRD/SD I/WD I
1	1800	23-12-2019	20-01-2020	Foundation & Plinth	1.2.4	210 kg/cm2	226.67	226.67	F.57/19-20/468.
	1801						226.67		Dt.03/01/2020
	1802						222.22		
2	1803	23-12-2019	20-01-2020	Foundation & Plinth	1.2.4	210 kg/cm2	231.11	226.67	do
	1804						226.67		
	1805						226.67		
3	1806	24-12-2019	21-01-2020	Foundation & Plinth	1.2.4	210 kg/cm2	226.67	226.67	
	1807						226.67		
	1808						226.67		
4	1809	24-12-2019	21-01-2020	Foundation & Plinth	1.2.4	210 kg/cm2	231.11	228.15	
	1810						226.67		
	1811						222.22		
5	1812	26-12-2019	23-01-2020	Foundation & Plinth	1.2.4	210 kg/cm2	217.78	220.74	
	1813						222.22		
	1814						217.78		
6	1815	26-12-2019	23-01-2020	Foundation & Plinth	1.2.4	210 kg/cm2	222.22	220.74	
	1816						222.22		
	1817						217.78		
7	1818	27-12-2019	24-01-2020	Foundation & Plinth	1.2.4	210 kg/cm2	222.22	222.22	
	1819						226.67		

**TECHNICAL ASSISTANT**  
**(Dhananjay R. Nagvenkar)**

**ASSISTANT ENGINEER**  
**(Pravin C. Parsekar)**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Development of Ramp at Bandreshwar Temple at Guddem at Village Siolim in Siolim Constituency.

**SAMPLE SENT BY:** AE, SD I, WD I, WRD, Porvorim, Goa.

**NAME OF THE AGENCY :**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
	1820						217.78		No. MI/WRD/SD I/WD I
1	1821	01-01-2020	29-01-2020	Foundation & Plinth	1.2.4	210 kg/cm2	213.33	216.30	F.57/19-20/468.
	1822						217.78		Dt.03/01/2020
	1823						217.78		
2	1824	01-01-2020	29-01-2020	Foundation & Plinth	1.2.4	210 kg/cm2	217.78	217.78	do
	1825						217.78		
	1826						213.33		
3	1827	02-01-2020	30-01-2020	Foundation & Plinth	1.2.4	210 kg/cm2	217.78	213.33	
	1828						208.89		
	1829						208.89		
4	1830	02-01-2020	30-01-2020	Foundation & Plinth	1.2.4	210 kg/cm2	213.33	213.33	
	1831						217.78		

**TECHNICAL ASSISTANT**  
(Dhananjay R. Nagvenkar)

**ASSISTANT ENGINEER**  
(Pravin C. Parsekar)