GOVERNMENT OF GOA QUALITY CONTROL LABORATORY WATER RESOURCES DEPARTMENT

Test Report No.: WRD / QC / F.6-2 / Cube -T : 708,709 & 739 / Lab /**207** /2020 - 21 Dated: - 23 /01 / 2021. Laboratory : Bicholim - Goa. Sub Division V (QC)/WRD/ Bicholim- Goa.

Name of work: Construction of RCC Bund at ch. 13.40 km of LBMC near intake point of water treatment plant at Assonora in Bardez-Taluka.

Ref. to Requisition No.: SD IV /WD VIII / WRD / F.410 /2020-21/ 125 Dated :- 29 / 12 / 2020.

Qty. Received.: 03 Sets of cube Date of Receipt:- 04/01/2021. Tested on: -17 & 21/01/2021 as per due dates. Ref to CPWD: 2009, Vol. I

Sample: Cube Mix 1:1.5:3 O.S No. :4732,4733 & 4755/SS. Lab. Sample No.: 9989,9990 & 9991 Tested By: Mrs. Sanmani Shirodkar, J.E.

PAGE 01 OF 01

SR. NO.	DISCRIPTION OF SAMPLE	TESTED FOR	RESULTS		Max./Min.Value permissable	% above or below	REMARK
1 1	Cement concrete cube of mix 1:1.5:3 , cast on 20/12/2020, for canal lining.	28 th day	283.16	Kg/Cm ²	265.00 Kg/cm ²	1 10 84 1	Qty represents - 28.00 Cum for Two set of cubes.
		compressive	292.22	Kg/Cm ²			
		strength	305.81	Kg/Cm ²			
		Average	293.73	Kg/Cm ²			
1 /	Cement concrete cube of mix 1:1.5:3, cast on 20/12/2020, for canal lining.	28 th day	289.95	Kg/Cm ²	265.00 Kg/cm ²	11.41	Do
		compressive	308.08	Kg/Cm ²			
		strength	287.69	Kg/Cm ²			
		Average	295.24	Kg/Cm ²			
1 3	Cement concrete cube of mix 1:1.5:3, cast on 24/12/2020, for RCC Bund.	28 th day	283.16	Kg/Cm ²	265.00 Kg/cm ²	7.14	Qty represents - 3.30 Cum.
		compressive	285.42	Kg/Cm ²			
		strength	283.16	Kg/Cm ²			
		Average	283.91	Kg/Cm ²			

Copy to: 1. The Assistant Engineer, SD IV, WD VIII, WRD, Dodamarg-Goa.

- 2. Copy submitted to: The Superintending Engineer ,CPO,WRD, Sinchai Bhavan, Porvorim Goa for kind Information.
- 3. Copy submitted to: The Executive Engineer, WDVIII, WRD, Karaswada Goa.
- 4. QC Lab File. 5. Bill File.

Junior Engineer

Assistant Engineer