

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Improvement of culvert across Bhiunsa Khariz and Dandora Bandh under Jurisdiction of Cuncolim Municipality in salcete Taluka.

SAMPLE SENT BY: AE, SD III, WD III, WRD, Gogol- Margao - Goa.

| NAME OF THE AGENCY | | | | TESTING PERIOD | | 28 days. | | | |
|--------------------|-------------|--------------|--------------|----------------------------|---------------|-------------------|--------------------|------------------|--------------------------|
| REPORT NO | SAMPLE NOS. | CASTING DATE | TESTING DATE | LOCATION OF SAMPLE | MIX PROPOTION | REQUIRED STRENGTH | Comp sth in Kg/cm2 | Avg. Comp Kg/cm2 | LETTER No / DATED |
| 1 | 2342 | | | | | | 186.67 | | No. 261/SD III/WDIII/ |
| | 2343 | 22-02-2021 | 22-03-2021 | Foundation Bhiunsa Culvert | 1.2.4 | 150 kg/cm2 | 186.67 | 185.19 | WRD/2020-21/395 |
| | 2344 | | | | | | 182.22 | | DATED: 01-03-2021 |
| 2 | 2345 | | | | | | 182.22 | | do |
| | 2346 | 23-02-2021 | 23-03-2021 | Dandora Cut off | 1.2.4 | 150 kg/cm2 | 182.22 | 183.70 | |
| | 2347 | | | | | | 186.67 | | |
| 3 | 2348 | | | | | | 168.89 | | do |
| | 2349 | 24-02-2021 | 24-03-2021 | Abutment | 1.2.4 | 150 kg/cm2 | 168.89 | 168.89 | |
| | 2350 | | | | | | 168.89 | | |
| 4 | 2351 | | | | | | 231.11 | | do |
| | 2352 | 27-02-2021 | 27-03-2021 | Slab | 1.1.5.3 | 200 kg/cm2 | 231.11 | 231.11 | |
| | 2353 | | | | | | 231.11 | | |

JUNIOR ENGINEER.

ASSISTANT ENGINEER