

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Retaining wall to the Storm water nallah in Sy No 189/1 at Sadovim ward in Verna village panchayat in Nuvem Constituency.

SAMPLE SENT BY: A.E, SD I, WD II, WRD,Aquem-Baixo,Rawanfond- Goa.

NAME OF THE AGENCY					TESTING PERIOD		28 days.		
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
	1						257.77		WRD/SDI/WDII/
1	2	25-09-2019	23-10-2019	All works upto Plinth level	1.2.4	210 kg/cm2	266.66	259.25	F.Esst/268/19-20
	3			Foundation			253.33		Dated 16/10/2019
	4						275.55		
2	5	26-09-2019	24-10-2019	All works upto Plinth level	1.2.4	210 kg/cm2	266.66	269.62	do
	6			Foundation			266.66		
	7						271.11		
3	8	27-09-2019	25-10-2019	All works upto Plinth level	1.2.4	210 kg/cm2	266.66	269.63	do
	9			Foundation			271.11		
	10						257.77		
4	11	28-09-2019	26-10-2019	All works upto Plinth level	1.2.4	210 kg/cm2	262.22	262.22	do
	12			Foundation			266.66		
	13						253.33		
5	14	30-09-2019	28-10-2019	All works upto Plinth level	1.2.4	210 kg/cm2	257.77	259.25	do
	15			Foundation			266.66		
	16						253.33		
6	17	1/10/2019	29-10-2019	All works upto Plinth level	1.2.4	210 kg/cm2	248.88	254.81	do
	18			Foundation			262.22		
	19						248.88		
7	20	3/10/2019	31-10-2019	All works upto Plinth level	1.2.4	210 kg/cm2	253.33	254.81	do
	21			Foundation			262.22		
	22						257.77		
8	23	4/10/2019	1/11/2019	in retaining wall	1.2.4	210 kg/cm2	248.88	254.81	do
	24						257.77		

Joaquim Antao
JUNIOR ENGINEER.

Pravin C Parsekar
ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Retaining wall to the Storm water nallah in Sy No 189/1at Sadovim ward in Verna village panchayatin Nuvem Constituency.

SAMPLE SENT BY: A.E, SD I, WD I, Porvorim- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX	REQUIRED	Comp sth in	Avg. Comp	LETTER No / DATED
	25						253.33		
1	26	5/10/2019	2/11/2019	in retaining wall	1.2.4	210 kg/cm2	253.33	254.81	
	27						257.77		
	28						248.88		
2	29	7/10/2019	4/11/2019	in retaining wall	1.2.4	210 kg/cm2	253.33	253.33	do
	30						257.77		
	31						266.66		
3	32	8/10/2019	5/11/2019	in retaining wall	1.2.4	210 kg/cm2	257.77	265.18	do
	33						271.11		
	34						271.11		
4	35	9/10/2019	6/11/2019	in retaining wall	1.2.4	210 kg/cm2	262.22	268.15	do
	36						271.11		
	37						262.22		
5	38	10/10/2019	7/11/2019	in retaining wall	1.2.4	210 kg/cm2	271.11	263.70	do
	39						257.77		
	40						266.66		
6	41	11/10/2019	8/11/2019	in retaining wall	1.2.4	210 kg/cm2	262.22	265.18	do
	42						266.66		

Joaquim Antao
JUNIOR ENGINEER.

Pravin C Parsekar
ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Retaining wall for the nallah in Survey No 77/17,Survey No 77/16,Survey No 77/1 at Poreibhat in V.P.Verna of Salcete Taluka.

SAMPLE SENT BY: A.E, SD I, WD II,WRD, MIC, Aquem-Baixo,Rawanfond - Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
	2322						244.44		No.WRD/SDI/ WDII/
1	2323	3/4/2019	1/5/2019	Foundation	1.2.4	210 kg/cm2	235.55	240.00	F.Esst/27/2019-2020
	2324						240.00		DATED:- 22-04-2019
	2325						244.44		
2	2326	3/4/2019	1/5/2019	Foundation	1.2.4	210 kg/cm2	248.88	244.44	do
	2327						240.00		
	2328						248.88		
3	2329	6/4/2019	4/5/2019	Foundation	1.2.4	210 kg/cm2	244.44	245.92	do
	2330						244.44		
	2331						244.44		
4	2332	6/4/2019	4/5/2019	Foundation	1.2.4	210 kg/cm2	235.55	242.96	do
	2333						248.88		
	2334						244.44		
5	2335	6/4/2019	4/5/2019	Foundation	1.2.4	210 kg/cm2	235.55	241.48	do
	2336						244.44		
	2337						235.55		
6	2338	6/4/2019	4/5/2019	Foundation	1.2.4	210 kg/cm2	248.88	242.96	do
	2339						244.44		
	2340						253.33		
7	2341	9/4/2019	7/5/2019	Wall	1.2.4	210 kg/cm2	244.44	244.44	do
	2342						235.55		
	2343						240.00		
8	2344	9/4/2019	7/5/2019	Wall	1.2.4	210 kg/cm2	235.55	241.48	do
	2345						248.88		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Retaining wall for the nallah in Survey No 77/17,Survey No 77/16,Survey No 77/1 at Poreibhat in V.P.Verna of Salcete Taluka.

SAMPLE SENT BY: A.E, SD I, WD II,WRD, MIC, Aquem-Baixo,Rawanfond - Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
	2346						244.44		No.WRD/SDI/ WDII/
1	2347	9/4/2019	7/5/2019	Wall	1.2.4	210 kg/cm2	240.00	242.96	F.Esst/27/2019-2020
	2348						244.44		DATED:- 22-04-2019
	2349						244.44		
2	2350	9/4/2019	7/5/2019	Wall	1.2.4	210 kg/cm2	248.88	244.44	do
	2351						240.00		
	2352						235.55		
3	2353	10/4/2019	8/5/2019	Wall	1.2.4	210 kg/cm2	244.44	241.48	do
	2354						244.44		
	2355						253.33		
4	2356	10/4/2019	8/5/2019	Wall	1.2.4	210 kg/cm2	240.00	242.96	do
	2357						235.55		
	2358						248.88		
5	2359	10/4/2019	8/5/2019	Wall	1.2.4	210 kg/cm2	235.55	244.44	do
	2360						248.88		
	2361						240.00		
6	2362	10/4/2019	8/5/2019	Wall	1.2.4	210 kg/cm2	235.55	242.96	do
	2363						253.33		
	2364						231.11		
7	2365	13/4/2019	11/5/2019	Wall	1.2.4	210 kg/cm2	253.33	241.48	do
	2366						240.00		
	2367						248.88		
8	2368	13/4/2019	11/5/2019	Wall	1.2.4	210 kg/cm2	231.11	242.96	do
	2369						248.88		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Retaining wall for the nallah in Survey No 77/17,Survey No 77/16,Survey No 77/1 at Poreibhat in V.P.Verna of Salcete Taluka.

SAMPLE SENT BY: A.E, SD I, WD II,WRD, MIC, Aquem-Baixo,Rawanfond - Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
	2370						235.55		No.WRD/SDI/ WDII/
1	2371	13/4/2019	11/5/2019	Wall	1.2.4	210 kg/cm2	248.88	242.96	F.Esst/27/2019-2020
	2372						244.44		DATED:- 22-04-2019
	2373						248.88		
2	2374	13/4/2019	11/5/2019	Wall	1.2.4	210 kg/cm2	253.33	245.92	do
	2375						235.55		
	2376						253.33		
3	2377	15/4/2019	13/5/2019	Wall	1.2.4	210 kg/cm2	231.11	241.48	do
	2378						240.00		
	2379						235.55		
4	2380	15/4/2019	13/5/2019	Wall	1.2.4	210 kg/cm2	244.44	242.96	do
	2381						248.88		

JUNIOR ENGINEER.

ASSISTANT ENGINEER