

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE \ Construction of protection wall for the nallah at Village Dulape- Verna in Sy.No. 274/5, Sy.No. 274/1 and 273/15 in Nuvem Constituency of Salcete Taluka.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Aquem Baixo, Rawanfond,Salcete Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	5642						106.67		No. WRD/ SD I/WD II/ F.Estt/ 44 /2021-22. DATED: 19-04-2021
	5643	15-04-2021	22-04-2021	Foundation	1.2.4	100 kg/cm2	111.11	111.11	
	5644						115.56		
1.2	5645						111.11		
	5646	15-04-2021	22-04-2021	Foundation	1.2.4	100 kg/cm2	111.11	112.59	do
	5647						115.56		
2	5648						115.56		
	5649	16-04-2021	23-04-2021	Wall	1.2.4	100 kg/cm2	111.11	112.59	do
	5650						111.11		
3.1	5651						106.67		
	5652	17-04-2021	24-04-2021	Wall	1.2.4	100 kg/cm2	115.56	111.11	do
	5653						111.11		
3.2	5654						111.11		
	5655	17-04-2021	24-04-2021	Wall	1.2.4	100 kg/cm2	111.11	112.59	do
	5656						115.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

**NAME OF THE **Construction of protection wall for the nallah at Village Dulape- Verna in Sy.No. 274/5, Sy.No. 274/1 and 273/15 in Nuvem Constituency of Salcete Taluka.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Aquem Baixo, Rawanfond,Salcete Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	5657						164.44		No. WRD/ SD I/WD II/
	5658	15-04-2021	13-05-2021	Foundation	1.2.4	150 kg/cm2	160.00	161.48	F.Estt/ 44 /2021-22.
	5659						160.00		DATED: 19-04-2021
2	5660						164.44		
	5661	16-04-2021	14-05-2021	Wall	1.2.4	150 kg/cm2	160.00	161.48	do
	5662						160.00		
3	5663						160.00		
	5664	17-04-2021	15-05-2021	Wall	1.2.4	150 kg/cm2	164.44	162.96	do
	5665						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER