

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of slab culvert for road access to the fields under Sy.No. 397/9, 397/6 and 397/8 of Chinchinim Village of Salcete Taluka for the year 2021-22.

SAMPLE SENT BY: AE, SD III, WD XIV, WRD, Cuncolim- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.6/10/2021						173.33		No. WRD/SD III/WD XIV/
	F.6/11/2021	18-11-2021	16-12-2021	Foundation of Culvert	1.2.4	150 kg/cm2	182.22	177.78	W.F.102/2021-2022/179.
	F.6/12/2021						177.78		DATED: 02-08-2021
2	F.6/13/2021						164.44		
	F.6/14/2021	20-11-2021	18-12-2021	Abutment wall of Culvert	1.2.4	150 kg/cm2	186.67	180.74	do
	F.6/15/2021						191.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of slab culvert for road access to the fields under Sy.No. 397/9, 397/6 and 397/8 of Chinchinim Village of Salcete Taluka for the year 2021-22.

SAMPLE SENT BY: AE, SD III, WD XIV, WRD, Cuncolim- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.6/16/2021						226.67		No. WRD/SD III/WD XIV/
	F.6/17/2021	22-11-2021	20-12-2021	SLAB Culvert	1. 1 1/2. 3	200 kg/cm2	231.11	229.63	W.F. 1/2021-2022/187.
	F.6/18/2021						231.11		DATED: 13-12-2021
2	F.6/19/2021						231.11		
	F.6/20/2021	22-11-2021	20-12-2021	SLAB Culvert	1. 1 1/2. 3	200 kg/cm2	226.67	231.11	do
	F.6/21/2021						235.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER