

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization of bank of nallah from Anthony Fernandes to Digamber Padwal house at Deulmol, Shirvoi in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.15/225/2021						164.44		No. WRD/WD XII/SD V/ F.15/123/2021-22 DATED:- 13-12-2021
	F.15/226/2021	4/12/2021	1/1/2022	Foundation	1.2.4	150 kg/cm2	160.00	162.96	
	F.15/227/2021						164.44		
1.2	F.15/228/2021						164.44		do
	F.15/229/2021	4/12/2021	1/1/2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.15/230/2021						168.89		
2	F.15/231/2021						164.44		do
	F.15/232/2021	6/12/2021	3/1/2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.15/233/2021						168.89		
3	F.15/234/2021						168.89		do
	F.15/235/2021	7/12/2021	4/1/2022	Foundation	1.2.4	150 kg/cm2	168.89	167.41	
	F.15/236/2021						164.44		
4.1	F.15/237/2021						164.44		do
	F.15/238/2021	8/12/2021	5/1/2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.15/239/2021			1st Lift			168.89		
4.2	F.15/240/2021						168.89		do
	F.15/241/2021	8/12/2021	5/1/2022	Foundation	1.2.4	150 kg/cm2	168.89	167.41	
	F.15/242/2021			1st Lift			164.44		
5.1	F.15/243/2021						168.89		do
	F.15/244/2021	9/12/2021	6/1/2022	Foundation	1.2.4	150 kg/cm2	168.89	167.41	
	F.15/245/2021						164.44		
5.2	F.15/246/2021						168.89		do
	F.15/247/2021	9/12/2021	6/1/2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.15/248/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization of bank of nallah from Anthony Fernandes to Digamber Padwal house at Deulmol, Shirvoi in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
6.1	F.15/249/2021						164.44		No. WRD/WD XII/SD V/
	F.15/250/2021	10/12/2021	7/1/2022	1st Lift	1.2.4	150 kg/cm2	160.00	162.96	F.15/123/2021-22
	F.15/251/2021						164.44		DATED:- 13-12-2021
6.2	F.15/252/2021						164.44		
	F.15/253/2021	10/12/2021	7/1/2022	1st Lift	1.2.4	150 kg/cm2	164.44	165.92	do
	F.15/254/2021						168.89		
7.1	F.15/255/2021						168.89		
	F.15/256/2021	11/12/2021	8/1/2022	1st Lift	1.2.4	150 kg/cm2	164.44	165.92	do
	F.15/257/2021						164.44		
7.2	F.15/258/2021						164.44		
	F.15/259/2021	11/12/2021	8/1/2022	1st Lift	1.2.4	150 kg/cm2	160.00	162.96	do
	F.15/260/2021						164.44		
8.1	F.15/261/2021						164.44		No. WRD/WD XII/SD V/
	F.15/262/2021	13-12-2021	10/1/2022	LHS Foundation	1.2.4	150 kg/cm2	160.00	162.96	F.15/135/2021-22
	F.15/263/2021						164.44		DATED:- 21-12-2021
8.2	F.15/264/2021						164.44		
	F.15/265/2021	13-12-2021	10/1/2022	LHS Foundation	1.2.4	150 kg/cm2	164.44	165.92	do
	F.15/266/2021						168.89		
9.1	F.15/267/2021						168.89		
	F.15/268/2021	14-12-2021	11/1/2022	RHS Foundation	1.2.4	150 kg/cm2	164.44	167.41	do
	F.15/269/2021						168.89		
9.2	F.15/270/2021						168.89		
	F.15/271/2021	14-12-2021	11/1/2022	RHS Foundation	1.2.4	150 kg/cm2	164.44	165.92	do
	F.15/272/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization of bank of nallah from Anthony Fernandes to Digamber Padwal house at Deulmol, Shirvoi in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
10.1	F.15/273/2021						164.44		No. WRD/WD XII/SD V/
	F.15/274/2021	15-12-2021	12/1/2022	RHS Foundation	1.2.4	150 kg/cm2	164.44	164.44	F.15/135/2021-22
	F.15/275/2021						164.44		DATED:- 21-12-2021
10.2	F.15/276/2021						168.89		
	F.15/277/2021	15-12-2021	12/1/2022	RHS Foundation	1.2.4	150 kg/cm2	164.44	165.92	do
	F.15/278/2021						164.44		
11.1	F.15/279/2021						164.44		
	F.15/280/2021	16-12-2021	13-01-2022	LHS 1st Lift	1.2.4	150 kg/cm2	160.00	162.96	do
	F.15/281/2021						164.44		
11.2	F.15/282/2021						164.44		
	F.15/283/2021	16-12-2021	13-01-2022	LHS 1st Lift	1.2.4	150 kg/cm2	164.44	165.92	do
	F.15/284/2021						168.89		
12	F.15/285/2021						168.89		
	F.15/286/2021	17-12-2021	14-01-2022	RHS 1st Lift	1.2.4	150 kg/cm2	164.44	165.92	do
	F.15/287/2021						164.44		
13.1	F.15/288/2021						164.44		
	F.15/289/2021	20-12-2021	17-01-2022	RHS 1st Lift	1.2.4	150 kg/cm2	160.00	162.96	do
	F.15/290/2021						164.44		
13.2	F.15/291/2021						164.44		
	F.15/292/2021	20-12-2021	17-01-2022	RHS 1st Lift	1.2.4	150 kg/cm2	160.00	162.96	do
	F.15/293/2021						164.44		
14.1	F.15/294/2021						164.44		No. WRD/WD XII/SD V/
	F.15/295/2021	21-12-2021	18-01-2022	LHS Foundation	1.2.4	150 kg/cm2	164.44	165.92	F.15/142/2021-22
	F.15/296/2021						168.89		DATED:- 28-12-2021

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization of bank of nallah from Anthony Fernandes to Digamber Padwal house at Deulmol, Shirvoi in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
14.2	F.15/297/2021						164.44		No. WRD/WD XII/SD V/ F.15/142/2021-22 DATED:- 28-12-2021
	F.15/298/2021	21-12-2021	18-01-2022	LHS Foundation	1.2.4	150 kg/cm2	160.00	162.96	
	F.15/299/2021						164.44		
14.3	F.15/300/2021						164.44		do
	F.15/301/2021	21-12-2021	18-01-2022	LHS Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.15/302/2021						168.89		
15.1	F.15/303/2021						168.89		do
	F.15/304/2021	22-12-2021	19-01-2022	LHS Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.15/305/2021			RHS Foundation			164.44		
15.2	F.15/306/2021						164.44		do
	F.15/307/2021	22-12-2021	19-01-2022	LHS Foundation	1.2.4	150 kg/cm2	160.00	162.96	
	F.15/308/2021			RHS Foundation			164.44		
15.3	F.15/309/2021						164.44		do
	F.15/310/2021	22-12-2021	19-01-2022	LHS Foundation	1.2.4	150 kg/cm2	160.00	162.96	
	F.15/311/2021			RHS Foundation			164.44		
16.1	F.15/312/2021						164.44		do
	F.15/313/2021	23-12-2021	20-01-2022	RHS Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.15/314/2021						168.89		
16.2	F.15/315/2021						168.89		do
	F.15/316/2021	23-12-2021	20-01-2022	RHS Foundation	1.2.4	150 kg/cm2	164.44	167.41	
	F.15/317/2021						168.89		
17.1	F.15/318/2021						168.89		do
	F.15/319/2021	24-12-2021	21-01-2022	LHS 1st Lift	1.2.4	150 kg/cm2	164.44	165.92	
	F.15/320/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization of bank of nallah from Anthony Fernandes to Digamber Padwal house at Deulmol, Shirvoi in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
17.2	F.15/321/2021						164.44		No. WRD/WD XII/SD V/
	F.15/322/2021	24-12-2021	21-01-2022	LHS 1st Lift	1.2.4	150 kg/cm2	160.00	162.96	F.15/142/2021-22
	F.15/323/2021						164.44		DATED:- 28-12-2021
18.1	F.15/324/2021						164.44		
	F.15/325/2021	25-12-2021	22-01-2022	RHS 1st Lift	1.2.4	150 kg/cm2	164.44	165.92	do
	F.15/326/2021						168.89		
18.2	F.15/327/2021						164.44		
	F.15/328/2021	25-12-2021	22-01-2022	RHS 1st Lift	1.2.4	150 kg/cm2	164.44	165.92	do
	F.15/329/2021						168.89		
18.3	F.15/330/2021						168.89		
	F.15/331/2021	25-12-2021	22-01-2022	RHS 1st Lift	1.2.4	150 kg/cm2	168.89	167.41	do
	F.15/332/2021						164.44		
19.1	F.15/333/2021						164.44		No. WRD/WD XII/SD V/
	F.15/334/2021	27-12-2021	24-01-2022	LHS Foundation	1.2.4	150 kg/cm2	164.44	165.92	F.15/149/2021-22
	F.15/335/2021						168.89		DATED:- 04-01-2022
19.2	F.15/336/2021						168.89		
	F.15/337/2021	27-12-2021	24-01-2022	LHS Foundation	1.2.4	150 kg/cm2	168.89	167.41	do
	F.15/338/2021						164.44		
19.3	F.15/339/2021						168.89		
	F.15/340/2021	27-12-2021	24-01-2022	LHS Foundation	1.2.4	150 kg/cm2	168.89	167.41	do
	F.15/341/2021						164.44		
19.4	F.15/342/2021						168.89		
	F.15/343/2021	27-12-2021	24-01-2022	LHS Foundation	1.2.4	150 kg/cm2	164.44	165.92	do
	F.15/344/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization of bank of nallah from Anthony Fernandes to Digamber Padwal house at Deulmol, Shirvoi in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
19.5	F.15/345/2021						164.44		No. WRD/WD XII/SD V/ F.15/149/2021-22 DATED:- 04-01-2022
	F.15/346/2021	27-12-2021	24-01-2022	LHS Foundation	1.2.4	150 kg/cm2	160.00	162.96	
	F.15/347/2021						164.44		
19.6	F.15/348/2021						164.44		do
	F.15/349/2021	27-12-2021	24-01-2022	LHS Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.15/350/2021						168.89		
20.1	F.15/351/2021						168.89		do
	F.15/352/2021	28-12-2021	25-01-2022	RHS Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.15/353/2021						164.44		
20.2	F.15/354/2021						164.44		do
	F.15/355/2021	28-12-2021	25-01-2022	RHS Foundation	1.2.4	150 kg/cm2	160.00	162.96	
	F.15/356/2021						164.44		
20.3	F.15/357/2021						164.44		do
	F.15/358/2021	28-12-2021	25-01-2022	RHS Foundation	1.2.4	150 kg/cm2	160.00	162.96	
	F.15/359/2021						164.44		
20.4	F.15/360/2021						164.44		do
	F.15/361/2021	28-12-2021	25-01-2022	RHS Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.15/362/2021						168.89		
21.1	F.15/363/2021						168.89		do
	F.15/364/2021	29-12-2021	26-01-2022	RHS Foundation	1.2.4	150 kg/cm2	164.44	167.41	
	F.15/365/2021						168.89		
21.2	F.15/366/2021						168.89		do
	F.15/367/2021	29-12-2021	26-01-2022	RHS Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.15/368/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization of bank of nallah from Anthony Fernandes to Digamber Padwal house at Deulmol, Shirvoi in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
22.1	F.15/369/2021						164.44		No. WRD/WD XII/SD V/ F.15/149/2021-22 DATED:- 04-01-2022
	F.15/370/2021	30-12-2021	27-01-2022	LHS 1st Lift	1.2.4	150 kg/cm2	160.00	162.96	
	F.15/371/2021						164.44		
22.2	F.15/372/2021						164.44		do
	F.15/373/2021	30-12-2021	27-01-2022	LHS 1st Lift	1.2.4	150 kg/cm2	164.44	165.92	
	F.15/374/2021						168.89		
22.3	F.15/375/2021						164.44		do
	F.15/376/2021	30-12-2021	27-01-2022	LHS 1st Lift	1.2.4	150 kg/cm2	164.44	165.92	
	F.15/377/2021						168.89		
22.4	F.15/378/2021						168.89		do
	F.15/379/2021	30-12-2021	27-01-2022	LHS 1st Lift	1.2.4	150 kg/cm2	168.89	167.41	
	F.15/380/2021						164.44		
23.1	F.15/381/2021						164.44		do
	F.15/382/2021	31-12-2021	28-01-2022	LHS 1st Lift	1.2.4	150 kg/cm2	164.44	165.92	
	F.15/383/2021			RHS 1st Lift			168.89		
23.2	F.15/384/2021						168.89		do
	F.15/385/2021	31-12-2021	28-01-2022	LHS 1st Lift	1.2.4	150 kg/cm2	168.89	167.41	
	F.15/386/2021			RHS 1st Lift			164.44		
23.3	F.15/387/2021						168.89		do
	F.15/388/2021	31-12-2021	28-01-2022	LHS 1st Lift	1.2.4	150 kg/cm2	168.89	167.41	
	F.15/389/2021			RHS 1st Lift			164.44		
23.4	F.15/390/2021						168.89		do
	F.15/391/2021	31-12-2021	28-01-2022	LHS 1st Lift	1.2.4	150 kg/cm2	164.44	165.92	
	F.15/392/2021			RHS 1st Lift			164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization of bank of nallah from Anthony Fernandes to Digamber Padwal house at Deulmol, Shirvoi in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
24.1	F.15/394/2021						164.44		No. WRD/WD XII/SD V/ F.15/149/2021-22 DATED:- 04-01-2022
	F.15/395/2021	1/1/2022	29-01-2022	RHS 1st Lift	1.2.4	150 kg/cm2	160.00	162.96	
	F.15/396/2021						164.44		
24.2	F.15/397/2021						164.44		do
	F.15/398/2021	1/1/2022	29-01-2022	RHS 1st Lift	1.2.4	150 kg/cm2	164.44	165.92	
	F.15/399/2021						168.89		
24.3	F.15/400/2021						168.89		do
	F.15/401/2021	1/1/2022	29-01-2022	RHS 1st Lift	1.2.4	150 kg/cm2	164.44	165.92	
	F.15/402/2021						164.44		
25.1	F.15/403/2021						164.44		do
	F.15/404/2021	3/1/2022	31-01-2022	RHS 1st Lift	1.2.4	150 kg/cm2	160.00	162.96	
	F.15/405/2021						164.44		
25.2	F.15/406/2021						164.44		do
	F.15/407/2021	3/1/2022	31-01-2022	RHS 1st Lift	1.2.4	150 kg/cm2	160.00	162.96	
	F.15/408/2021						164.44		
25.3	F.15/409/2021						164.44		do
	F.15/410/2021	3/1/2022	31-01-2022	RHS 1st Lift	1.2.4	150 kg/cm2	164.44	165.92	
	F.15/411/2021						168.89		
26.1	F.15/412/2021						168.89		No. WRD/WD XII/SD V/ F.15/158/2021-22 DATED:- 14-01-2022
	F.15/413/2021	6/1/2022	3/2/2022	LHS Foundation	1.2.4	150 kg/cm2	164.44	167.41	
	F.15/414/2021						168.89		
26.2	F.15/415/2021						168.89		do
	F.15/416/2021	6/1/2022	3/2/2022	LHS Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.15/417/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Stabilization of bank of nallah from Anthony Fernandes to Digamber Padwal house at Deulmol, Shirvoi in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY				TESTING PERIOD		28 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
26.3	F.15/418/2021						168.89		No. WRD/WD XII/SD V/ F.15/158/2021-22 DATED:- 14-01-2022
	F.15/419/2021	6/1/2022	3/2/2022	LHS Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.15/420/2021						164.44		
26.4	F.15/421/2021						164.44		
	F.15/422/2021	6/1/2022	3/2/2022	LHS Foundation	1.2.4	150 kg/cm2	160.00	162.96	do
	F.15/423/2021						164.44		
27.1	F.15/424/2021						164.44		
	F.15/425/2021	7/1/2022	4/2/2022	LHS 1st Lift	1.2.4	150 kg/cm2	164.44	165.92	do
	F.15/426/2021						168.89		
27.2	F.15/427/2021						168.89		
	F.15/428/2021	7/1/2022	4/2/2022	LHS 1st Lift	1.2.4	150 kg/cm2	164.44	165.92	do
	F.15/429/2021						164.44		
28.1	F.15/430/2021						164.44		
	F.15/431/2021	8/1/2022	5/2/2022	LHS 1st Lift	1.2.4	150 kg/cm2	160.00	162.96	do
	F.15/432/2021						164.44		
28.2	F.15/433/2021						164.44		
	F.15/434/2021	8/1/2022	5/2/2022	LHS 1st Lift	1.2.4	150 kg/cm2	160.00	162.96	do
	F.15/435/2021						164.44		
29	F.15/436/2021						164.44		
	F.15/437/2021	10/1/2022	7/2/2022	LHS 2nd Lift	1.2.4	150 kg/cm2	164.44	165.92	do
	F.15/438/2021						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization of bank of nallah from Anthony Fernandes to Digamber Padwal house at Deulmol, Shirvoi in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
30.1	F.15/439/2021						168.89		No. WRD/WD XII/SD V/
	F.15/440/2021	22-02-2022	22-03-2022	RHS 1st Lift	1.2.4	150 kg/cm2	168.89	167.41	F.15/188/2021-22
	F.15/441/2021						164.44		DATED:- 25-02-2022
30.2	F.15/442/2021						164.44		
	F.15/443/2021	22-02-2022	22-03-2022	RHS 1st Lift	1.2.4	150 kg/cm2	168.89	165.92	do
	F.15/444/2021						164.44		
31.1	F.15/445/2021						164.44		
	F.15/446/2021	23-02-2022	23-03-2022	RHS 2nd Lift	1.2.4	150 kg/cm2	164.44	164.44	do
	F.15/447/2021						164.44		
31.2	F.15/448/2021						168.89		
	F.15/449/2021	23-02-2022	23-03-2022	RHS 2nd Lift	1.2.4	150 kg/cm2	164.44	165.92	do
	F.15/450/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER