

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of slab culvert for road access to the fields under Sy.No. 397/9, 397/6 and 397/8 of Chinchinim Village of Salcete Taluka for the year 2021-22.

**SAMPLE SENT BY:** AE, SD III, WD XIV, WRD, Cuncolim- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.6/4/2021						115.56		No. WRD/SD III/WD XIV/
	F.6/5/2021	18-11-2021	25-11-2021	Foundation of Culvert	1.2.4	100 kg/cm2	120.00	118.52	W.F.102/2021-2022/179.
	F.6/6/2021						120.00		<b>DATED: 02-08-2021</b>
2	F.6/7/2021						115.56		
	F.6/8/2021	20-11-2021	27-11-2021	Abutment wall of Culvert	1.2.4	100 kg/cm2	120.00	115.56	do
	F.6/9/2021						111.11		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**