

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization of bank of nallah from Anthony Fernandes to Digamber Padwal house at Deulmol, Shirvoi in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.15/06/2021						115.56		No. WRD/WD XII/SD V/ F.15/123/2021-22 DATED:- 13-12-2021
	F.15/07/2021	6/12/2021	13-12-2021	Foundation	1.2.4	100 kg/cm2	120.00	118.52	
	F.15/08/2021						120.00		
2	F.15/09/2021						115.56		do
	F.15/10/2021	7/12/2021	14-12-2021	Foundation	1.2.4	100 kg/cm2	120.00	115.56	
	F.15/11/2021						111.11		
3.1	F.15/12/2021						115.56		do
	F.15/13/2021	8/12/2021	15-12-2021	Foundation	1.2.4	100 kg/cm2	124.44	117.04	
	F.15/14/2021			1st Lift			111.11		
3.2	F.15/15/2021						120.00		do
	F.15/16/2021	8/12/2021	15-12-2021	Foundation	1.2.4	100 kg/cm2	120.00	117.04	
	F.15/17/2021			1st Lift			111.11		
4.1	F.15/18/2021						115.56		do
	F.15/19/2021	9/12/2021	16-12-2021	Foundation	1.2.4	100 kg/cm2	115.55	117.04	
	F.15/20/2021						120.00		
4.2	F.15/21/2021						115.56		do
	F.15/22/2021	9/12/2021	16-12-2021	Foundation	1.2.4	100 kg/cm2	115.56	115.56	
	F.15/23/2021						115.56		
5.1	F.15/24/2021						111.11		do
	F.15/25/2021	10/12/2021	17-12-2021	1st Lift	1.2.4	100 kg/cm2	115.56	115.56	
	F.15/26/2021						120.00		
5.2	F.15/27/2021						115.56		do
	F.15/28/2021	10/12/2021	17-12-2021	1st Lift	1.2.4	100 kg/cm2	115.56	117.04	
	F.15/29/2021						120.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization of bank of nallah from Anthony Fernandes to Digamber Padwal house at Deulmol, Shirvoi in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
6.1	F.15/30/2021						115.56		No. WRD/WD XII/SD V/
	F.15/31/2021	11/12/2021	18-12-2021	1st Lift	1.2.4	100 kg/cm2	120.00	118.52	F.15/123/2021-22
	F.15/32/2021						120.00		DATED:- 13-12-2021
6.2	F.15/33/2021						115.56		
	F.15/34/2021	11/12/2021	18-12-2021	1st Lift	1.2.4	100 kg/cm2	120.00	115.56	do
	F.15/35/2021						111.11		
7.1	F.15/36/2021						115.56		No. WRD/WD XII/SD V/
	F.15/37/2021	14-12-2021	21-12-2021	RHS Foundation	1.2.4	100 kg/cm2	124.44	117.04	F.15/135/2021-22
	F.15/38/2021						111.11		DATED:- 21-12-2021
7.2	F.15/39/2021						120.00		
	F.15/40/2021	14-12-2021	21-12-2021	RHS Foundation	1.2.4	100 kg/cm2	115.56	118.52	do
	F.15/41/2021						120.00		
8.1	F.15/90/2021						120.00		
	F.15/91/2021	15-12-2021	22-12-2021	RHS Foundation	1.2.4	100 kg/cm2	120.00	117.04	do
	F.15/92/2021						111.11		
8.2	F.15/93/2021						115.56		
	F.15/94/2022	15-12-2021	22-12-2021	RHS Foundation	1.2.4	100 kg/cm2	115.55	117.04	do
	F.15/95/2022						120.00		
9.1	F.15/96/2022						115.56		
	F.15/97/2023	16-12-2021	23-12-2021	LHS 1st Lift	1.2.4	100 kg/cm2	115.56	115.56	do
	F.15/98/2023						115.56		
9.2	F.15/99/2023						111.11		
	F.15/100/2024	16-12-2021	23-12-2021	LHS 1st Lift	1.2.4	100 kg/cm2	115.56	115.56	do
	F.15/101/2024						120.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization of bank of nallah from Anthony Fernandes to Digamber Padwal house at Deulmol, Shirvoi in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
10	F.15/102/2021						115.56		No. WRD/WD XII/SD V/
	F.15/103/2021	17-12-2021	24-12-2021	RHS 1st Lift	1.2.4	100 kg/cm2	120.00	115.56	F.15/135/2021-22
	F.15/104/2021						111.11		DATED:- 21-12-2021
11.1	F.15/105/2021						115.56		
	F.15/106/2021	20-12-2021	27-12-2021	RHS 1st Lift	1.2.4	100 kg/cm2	124.44	117.04	do
	F.15/107/2021						111.11		
11.2	F.15/108/2021						120.00		
	F.15/109/2021	20-12-2021	27-12-2021	RHS 1st Lift	1.2.4	100 kg/cm2	115.56	118.52	do
	F.15/110/2021						120.00		
12.1	F.15/111/2021						120.00		No. WRD/WD XII/SD V/
	F.15/112/2021	21-12-2021	28-12-2021	LHS Foundation	1.2.4	100 kg/cm2	120.00	117.04	F.15/142/2021-22
	F.15/113/2021						111.11		DATED:- 28-12-2021
12.2	F.15/114/2021						115.56		
	F.15/115/2021	21-12-2021	28-12-2021	LHS Foundation	1.2.4	100 kg/cm2	115.55	117.04	do
	F.15/116/2021						120.00		
12.3	F.15/117/2021						120.00		
	F.15/118/2021	21-12-2021	28-12-2021	LHS Foundation	1.2.4	100 kg/cm2	120.00	117.04	do
	F.15/119/2021						111.11		
13.1	F.15/120/2021						115.56		
	F.15/121/2022	22-12-2021	29-12-2021	LHS Foundation	1.2.4	100 kg/cm2	115.55	117.04	do
	F.15/122/2022			RHS Foundation			120.00		
13.2	F.15/123/2022						115.56		
	F.15/124/2023	22-12-2021	29-12-2021	LHS Foundation	1.2.4	100 kg/cm2	115.56	115.56	do
	F.15/125/2023			RHS Foundation			115.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization of bank of nallah from Anthony Fernandes to Digamber Padwal house at Deulmol, Shirvoi in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
13.3	F.15/126/2021						115.56		No. WRD/WD XII/SD V/
	F.15/127/2021	22-12-2021	29-12-2021	LHS Foundation	1.2.4	100 kg/cm2	120.00	118.52	F.15/142/2021-22
	F.15/128/2021			RHS Foundation			120.00		DATED:- 28-12-2021
14.1	F.15/129/2021						115.56		
	F.15/130/2021	23-12-2021	30-12-2021	RHS Foundation	1.2.4	100 kg/cm2	120.00	115.56	do
	F.15/131/2021						111.11		
14.2	F.15/132/2021						115.56		
	F.15/133/2021	23-12-2021	30-12-2021	RHS Foundation	1.2.4	100 kg/cm2	124.44	117.04	do
	F.15/134/2021						111.11		
15.1	F.15/135/2021						120.00		
	F.15/136/2021	24-12-2021	31-12-2021	LHS 1st Lift	1.2.4	100 kg/cm2	115.56	118.52	do
	F.15/137/2021						120.00		
15.2	F.15/138/2021						120.00		
	F.15/139/2021	24-12-2021	31-12-2021	LHS 1st Lift	1.2.4	100 kg/cm2	120.00	117.04	do
	F.15/140/2021						111.11		
16.1	F.15/141/2021						115.56		
	F.15/142/2022	25-12-2021	1/1/2022	RHS 1st Lift	1.2.4	100 kg/cm2	115.55	117.04	do
	F.15/143/2022						120.00		
16.2	F.15/144/2022						115.56		
	F.15/145/2023	25-12-2021	1/1/2022	RHS 1st Lift	1.2.4	100 kg/cm2	115.56	115.56	do
	F.15/146/2023						115.56		
16.3	F.15/147/2023						111.11		
	F.15/148/2024	25-12-2021	1/1/2022	RHS 1st Lift	1.2.4	100 kg/cm2	115.56	115.56	do
	F.15/149/2024						120.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization of bank of nallah from Anthony Fernandes to Digamber Padwal house at Deulmol, Shirvoi in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
17.1	F.15/150/2021						115.56		No. WRD/WD XII/SD V/ F.15/149/2021-22 DATED:- 04-01-2022
	F.15/151/2021	28-12-2021	4/1/2022	RHS Foundation	1.2.4	100 kg/cm2	120.00	118.52	
	F.15/152/2021						120.00		
17.2	F.15/153/2021						115.56		do
	F.15/154/2021	28-12-2021	4/1/2022	RHS Foundation	1.2.4	100 kg/cm2	120.00	115.56	
	F.15/155/2021						111.11		
17.3	F.15/156/2021						115.56		do
	F.15/157/2021	28-12-2021	4/1/2022	RHS Foundation	1.2.4	100 kg/cm2	124.44	117.04	
	F.15/158/2021			1st Lift			111.11		
17.4	F.15/159/2021						120.00		do
	F.15/160/2021	28-12-2021	4/1/2022	RHS Foundation	1.2.4	100 kg/cm2	120.00	117.04	
	F.15/161/2021			1st Lift			111.11		
18.1	F.15/162/2021						115.56		do
	F.15/163/2021	29-12-2021	5/1/2022	RHS Foundation	1.2.4	100 kg/cm2	115.55	117.04	
	F.15/164/2021						120.00		
18.2	F.15/165/2021						115.56		do
	F.15/166/2021	29-12-2021	5/1/2022	RHS Foundation	1.2.4	100 kg/cm2	115.56	115.56	
	F.15/167/2021						115.56		
19.1	F.15/168/2021						111.11		do
	F.15/169/2021	30-12-2021	6/1/2022	LHS 1st Lift	1.2.4	100 kg/cm2	115.56	115.56	
	F.15/170/2021						120.00		
19.2	F.15/171/2021						115.56		do
	F.15/172/2021	30-12-2021	6/1/2022	LHS 1st Lift	1.2.4	100 kg/cm2	115.56	117.04	
	F.15/173/2021						120.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization of bank of nallah from Anthony Fernandes to Digamber Padwal house at Deulmol, Shirvoi in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
19.3	F.15/174/2021						115.56		No. WRD/WD XII/SD V/ F.15/149/2021-22 DATED:- 04-01-2022
	F.15/175/2021	30-12-2021	6/1/2022	LHS 1st Lift	1.2.4	100 kg/cm2	120.00	118.52	
	F.15/176/2021						120.00		
19.4	F.15/177/2021						115.56		do
	F.15/178/2021	30-12-2021	6/1/2022	LHS 1st Lift	1.2.4	100 kg/cm2	120.00	115.56	
	F.15/179/2021						111.11		
20.1	F.15/180/2021						115.56		do
	F.15/181/2021	31-12-2021	7/1/2022	LHS 1st Lift	1.2.4	100 kg/cm2	124.44	117.04	
	F.15/182/2021			RHS 1st Lift			111.11		
20.2	F.15/183/2021						120.00		do
	F.15/184/2021	31-12-2021	7/1/2022	LHS 1st Lift	1.2.4	100 kg/cm2	115.56	118.52	
	F.15/185/2021			RHS 1st Lift			120.00		
20.3	F.15/186/2021						120.00		do
	F.15/187/2021	31-12-2021	7/1/2022	LHS 1st Lift	1.2.4	100 kg/cm2	120.00	117.04	
	F.15/188/2021			RHS 1st Lift			111.11		
20.4	F.15/189/2021						115.56		do
	F.15/190/2022	31-12-2021	7/1/2022	LHS 1st Lift	1.2.4	100 kg/cm2	115.55	117.04	
	F.15/191/2022			RHS 1st Lift			120.00		
21.1	F.15/192/2022						115.56		do
	F.15/193/2023	1/1/2022	8/1/2022	RHS 1st Lift	1.2.4	100 kg/cm2	115.56	115.56	
	F.15/194/2023						115.56		
21.2	F.15/195/2023						111.11		do
	F.15/196/2024	1/1/2022	8/1/2022	RHS 1st Lift	1.2.4	100 kg/cm2	115.56	115.56	
	F.15/197/2024						120.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization of bank of nallah from Anthony Fernandes to Digamber Padwal house at Deulmol, Shirvoi in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
21.3	F.15/198/2021						115.56		No. WRD/WD XII/SD V/
	F.15/199/2021	1/1/2022	8/1/2022	RHS 1st Lift	1.2.4	100 kg/cm2	120.00	115.56	F.15/149/2021-22
	F.15/200/2021						111.11		DATED:- 04-01-2022
22.1	F.15/201/2021						115.56		
	F.15/202/2021	3/1/2022	10/1/2022	RHS 1st Lift	1.2.4	100 kg/cm2	124.44	117.04	do
	F.15/203/2021						111.11		
22.2	F.15/204/2021						120.00		
	F.15/205/2021	3/1/2022	10/1/2022	RHS 1st Lift	1.2.4	100 kg/cm2	115.56	118.52	do
	F.15/206/2021						120.00		
22.3	F.15/207/2021						120.00		
	F.15/208/2021	3/1/2022	10/1/2022	RHS 1st Lift	1.2.4	100 kg/cm2	120.00	117.04	do
	F.15/209/2021						111.11		
23.1	F.15/210/2021						115.56		No. WRD/WD XII/SD V/
	F.15/211/2021	7/1/2022	14-01-2022	LHS 1st Lift	1.2.4	100 kg/cm2	115.55	117.04	F.15/158/2021-22
	F.15/212/2021						120.00		DATED:- 14-01-2022
23.2	F.15/213/2021						120.00		
	F.15/214/2021	7/1/2022	14-01-2022	LHS 1st Lift	1.2.4	100 kg/cm2	120.00	117.04	do
	F.15/215/2021						111.11		
24.1	F.15/216/2021						115.56		
	F.15/217/2022	8/1/2022	15-01-2022	LHS 1st Lift	1.2.4	100 kg/cm2	115.55	117.04	do
	F.15/218/2022						120.00		
24.2	F.15/219/2022						115.56		
	F.15/220/2023	8/1/2022	15-01-2022	LHS 1st Lift	1.2.4	100 kg/cm2	115.56	115.56	do
	F.15/221/2023						115.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization of bank of nallah from Anthony Fernandes to Digamber Padwal house at Deulmol, Shirvoi in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
25	F.15/222/2021						115.56		No. WRD/WD XII/SD V/
	F.15/223/2021	10/1/2022	17-01-2022	LHS 2nd Lift	1.2.4	100 kg/cm2	120.00	118.52	F.15/158/2021-22
	F.15/224/2021						120.00		DATED:- 14-01-2022

JUNIOR ENGINEER.

ASSISTANT ENGINEER