

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Ganesh Visarjan tank at Thorbhat Dutalewada in Ward No. 9 of Marcaim Constituency of Ponda Taluka.

**SAMPLE SENT BY:** AE, SD IV, WD XI, WRD, Ponda- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm <sup>2</sup>	Avg. Comp Kg/cm <sup>2</sup>	LETTER No / DATED
1	F.13/31/2021						124.44		No. WRD/WD XI/ SD IV/
	F.13/32/2021	1/12/2021	29-12-2021	Tank Foundation	1.3.6	100 kg/cm <sup>2</sup>	124.44	125.92	F.CF/400/2021-22.
	F.13/33/2021						128.89		<b>DATED: 08-12-2021</b>
2	F.13/34/2021						128.89		
	F.13/35/2021	2/12/2021	30-12-2021	Tank Foundation	1.3.6	100 kg/cm <sup>2</sup>	128.89	127.41	do
	F.13/36/2021						124.44		
3.1	F.13/37/2021						128.89		
	F.13/38/2021	4/12/2021	1/1/2022	Tank Wall	1.3.6	100 kg/cm <sup>2</sup>	124.44	127.41	do
	F.13/39/2021						128.89		
3.2	F.13/40/2021						124.44		
	F.13/41/2021	4/12/2021	1/1/2022	Tank Wall	1.3.6	100 kg/cm <sup>2</sup>	128.89	125.92	do
	F.13/42/2021						124.44		
4.1	F.13/43/2021						128.89		
	F.13/44/2021	6/12/2021	3/1/2022	Tank Wall	1.3.6	100 kg/cm <sup>2</sup>	128.89	127.41	do
	F.13/45/2021						124.44		
4.2	F.13/46/2021						120.00		
	F.13/47/2021	6/12/2021	3/1/2022	Tank Wall	1.3.6	100 kg/cm <sup>2</sup>	124.44	121.48	do
	F.13/48/2021						120.00		
5	F.13/49/2021						124.44		
	F.13/50/2021	7/12/2021	4/1/2022	Tank Wall	1.3.6	100 kg/cm <sup>2</sup>	128.89	127.41	do
	F.13/51/2021						128.89		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of Ganesh Visarjan tank at Thorbhat Dutale in Ward No. 9 of Marcaim Constituency of Ponda Taluka.

**SAMPLE SENT BY:** AE, SD IV, WD XI, WRD, Ponda- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm <sup>2</sup>	Avg. Comp Kg/cm <sup>2</sup>	LETTER No / DATED
1	F.13/58/2021						128.89		No. WRD/WD XI/ SD IV/
	F.13/59/2021	30-12-2021	27-01-2022	Wall Foundation, platform and steps	1.3.6	100 kg/cm <sup>2</sup>	124.44	127.41	F.CF/433/2021-22.
	F.13/60/2021						128.89		<b>DATED: 06-01-2022</b>
2	F.13/61/2021						124.44		
	F.13/62/2021	31-12-2021	28-01-2022	Wall top and horizontal top belt	1.3.6	100 kg/cm <sup>2</sup>	128.89	125.92	do
	F.13/63/2021						124.44		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**