

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Ganesh Visarjan tank at Thorbhat Dutale in Ward No. 9 of Marcaim Constituency of Ponda Taluka.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.13/10/2021						80.00		No. WRD/WD XI/ SD IV/ F.CF/400/2021-22. DATED: 08-12-2021
	F.13/11/2021	1/12/2021	8/12/2021	Tank Foundation	1.3.6	70 kg/cm2	75.56	77.04	
	F.13/12/2021						75.56		
2	F.13/13/2021						75.56		do
	F.13/14/2021	2/12/2021	9/12/2021	Tank Foundation	1.3.6	70 kg/cm2	75.56	74.08	
	F.13/15/2021						71.11		
3.1	F.13/16/2021						80.00		do
	F.13/17/2021	4/12/2021	11/12/2021	Tank Wall	1.3.6	70 kg/cm2	75.56	78.52	
	F.13/18/2021						80.00		
3.2	F.13/19/2021						75.56		do
	F.13/20/2021	4/12/2021	11/12/2021	Tank Wall	1.3.6	70 kg/cm2	80.00	78.52	
	F.13/21/2021						80.00		
4.1	F.13/22/2021						75.56		do
	F.13/23/2021	6/12/2021	13-12-2021	Tank Wall	1.3.6	70 kg/cm2	75.56	74.08	
	F.13/24/2021						71.11		
4.2	F.13/25/2021						75.56		do
	F.13/26/2021	6/12/2021	13-12-2021	Tank Wall	1.3.6	70 kg/cm2	71.11	74.08	
	F.13/27/2021						75.56		
5	F.13/28/2021						71.11		do
	F.13/29/2021	7/12/2021	14-12-2021	Tank Wall	1.3.6	70 kg/cm2	75.56	75.56	
	F.13/30/2021						80.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Ganesh Visarjan tank at Thorbhat Dutale in Ward No. 9 of Marcaim Constituency of Ponda Taluka.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.13/52/2021						80.00		No. WRD/WD XI/ SD IV/
	F.13/53/2021	30-12-2021	6/1/2022	Wall Foundation, platform and steps	1.3.6	70 kg/cm2	80.00	78.52	F.CF/433/2021-22.
	F.13/54/2021						75.56		DATED: 06-01-2022
2	F.13/55/2021						75.56		
	F.13/56/2021	31-12-2021	7/1/2022	Wall top and horizontal top belt	1.3.6	70 kg/cm2	80.00	77.04	do
	F.13/57/2021						75.56		

JUNIOR ENGINEER.

ASSISTANT ENGINEER