

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of retaining wall in Sy.No. 64/18 in V.P. Davorlim in Navelim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.90/05/2021						168.89		No. WRD/SD I/ WD II/ F.Esst/724/2021-22 DATED:- 07-02-2022.
	F.90/06/2021	2/2/2022	2/3/2022	Foundation	1.2.4	150 kg/cm2	168.89	168.89	
	F.90/07/2021						168.89		
1.2	F.90/08/2021						164.44		do
	F.90/09/2021	2/2/2022	2/3/2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.90/10/2021						168.89		
2.1	F.90/11/2021						164.44		do
	F.90/12/2021	3/2/2022	3/3/2022	Foundation & Wall	1.2.4	150 kg/cm2	168.89	167.41	
	F.90/13/2021						168.89		
2.2	F.90/14/2021						168.89		do
	F.90/15/2021	3/2/2022	3/3/2022	Foundation & Wall	1.2.4	150 kg/cm2	164.44	167.41	
	F.90/16/2021						168.89		
3.1	F.90/17/2021						168.89		do
	F.90/18/2021	4/2/2022	4/3/2022	Wall	1.2.4	150 kg/cm2	164.44	167.41	
	F.90/19/2021						168.89		
3.2	F.90/20/2021						168.89		do
	F.90/21/2021	4/2/2022	4/3/2022	Wall	1.2.4	150 kg/cm2	168.89	168.89	
	F.90/22/2021						168.89		
4.1	F.90/23/2021						168.89		do
	F.90/24/2021	5/2/2022	5/3/2022	Wall	1.2.4	150 kg/cm2	164.44	167.41	
	F.90/25/2021						168.89		
4.2	F.90/26/2021						168.89		do
	F.90/27/2021	5/2/2022	5/3/2022	Wall	1.2.4	150 kg/cm2	168.89	168.89	
	F.90/28/2021						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of retaining wall in Sy.No. 64/18 in V.P. Davorlim in Navelim Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
4.3	F.90/29/2021						168.89		No. WRD/SD I/ WD II/
	F.90/30/2021	5/2/2022	5/3/2022	Wall	1.2.4	150 kg/cm2	164.44	167.41	F.Esst/724/2021-22
	F.90/31/2021						168.89		DATED:- 07-02-2022.
4.4	F.90/32/2021						164.44		
	F.90/33/2021	5/2/2022	5/3/2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	do
	F.90/34/2021						168.89		
5.1	F.90/35/2021						164.44		
	F.90/36/2021	7/2/2022	7/3/2022	Wall	1.2.4	150 kg/cm2	168.89	167.41	do
	F.90/37/2021						168.89		
5.2	F.90/38/2021						164.44		
	F.90/39/2021	7/2/2022	7/3/2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	do
	F.90/40/2021						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER