

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Improvement to nallah near Vasudev Vernekar at Thana in Cortalim Constituency.

**SAMPLE SENT BY:** AE, SD II, WD II, WRD, Gogol- Margao- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm <sup>2</sup>	Avg. Comp Kg/cm <sup>2</sup>	LETTER No / DATED
1.1	F.18/05/2021						124.44		No. WRD/WD II/ SD II/ F.03/263/2021-22. <b>DATED: 28-12-2021</b>
	F.18/06/2021	21-12-2021	18-01-2022	Foundation Ch.0 mt to Ch 30 mts	1.3.6	100 kg/cm <sup>2</sup>	124.44	125.92	
	F.18/07/2021						128.89		
1.2	F.18/08/2021						128.89		do
	F.18/09/2021	21-12-2021	18-01-2022	Foundation Ch.0 mt to Ch 30 mts	1.3.6	100 kg/cm <sup>2</sup>	128.89	127.41	
	F.18/10/2021						124.44		
1.3	F.18/11/2021						128.89		do
	F.18/12/2021	21-12-2021	18-01-2022	Foundation Ch.0 mt to Ch 30 mts	1.3.6	100 kg/cm <sup>2</sup>	124.44	127.41	
	F.18/13/2021						128.89		
1.4	F.18/14/2021						124.44		do
	F.18/15/2021	21-12-2021	18-01-2022	Foundation Ch.0 mt to Ch 30 mts	1.3.6	100 kg/cm <sup>2</sup>	128.89	125.92	
	F.18/16/2021						124.44		
2.1	F.18/17/2021						128.89		do
	F.18/18/2021	22-12-2021	19-01-2022	Foundation Ch. 30 mt to Ch 56 mts	1.3.6	100 kg/cm <sup>2</sup>	128.89	127.41	
	F.18/19/2021						124.44		
2.2	F.18/20/2021						120.00		do
	F.18/21/2021	22-12-2021	19-01-2022	Foundation Ch. 30 mt to Ch 56 mts	1.3.6	100 kg/cm <sup>2</sup>	124.44	121.48	
	F.18/22/2021						120.00		
2.3	F.18/23/2021						124.44		do
	F.18/24/2021	22-12-2021	19-01-2022	Foundation Ch. 30 mt to Ch 56 mts	1.3.6	100 kg/cm <sup>2</sup>	128.89	127.41	
	F.18/25/2021						128.89		
2.4	F.18/26/2021						124.44		do
	F.18/27/2021	22-12-2021	19-01-2022	Foundation Ch. 30 mt to Ch 56 mts	1.3.6	100 kg/cm <sup>2</sup>	120.00	122.96	
	F.18/28/2021						124.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

## SD III (QC) , WRD, GOGAL, MARGAO- GOA.

**NAME OF THE WORK:** Improvement to nallah near Vasudev Vernekar at Thana in Cortalim Constituency.

**SAMPLE SENT BY:** AE, SD II, WD II, WRD, Gogol- Margao- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
3.1	F.18/29/2021						128.89		No. WRD/WD II/ SD II/ F.03/263/2021-22. <b>DATED: 28-12-2021</b>
	F.18/30/2021	24-12-2021	21-01-2022	Above Foundation Ch.0 mt to Ch 30 mts	1.3.6	100 kg/cm2	124.44	127.41	
	F.18/31/2021						128.89		
3.2	F.18/32/2021						128.89		
	F.18/33/2021	24-12-2021	21-01-2022	Above Foundation Ch.0 mt to Ch 30 mts	1.3.6	100 kg/cm2	128.89	128.89	do
	F.18/34/2021						128.89		
3.3	F.18/35/2021						128.89		
	F.18/36/2021	24-12-2021	21-01-2022	Above Foundation Ch.0 mt to Ch 30 mts	1.3.6	100 kg/cm2	124.44	127.41	do
	F.18/36/2021						128.89		
3.4	F.18/38/2021						128.89		
	F.18/39/2021	24-12-2021	21-01-2022	Above Foundation Ch.0 mt to Ch 30 mts	1.3.6	100 kg/cm2	128.89	127.41	do
	F.18/40/2021						124.44		
4.1	F.18/41/2021						128.89		
	F.18/42/2021	25-12-2021	22-01-2022	Above Foundation Ch. 30 mt to Ch 56 mts	1.3.6	100 kg/cm2	128.89	128.89	do
	F.18/43/2021						128.89		
4.2	F.18/44/2021						124.44		
	F.18/45/2021	25-12-2021	22-01-2022	Above Foundation Ch. 30 mt to Ch 56 mts	1.3.6	100 kg/cm2	124.44	124.44	do
	F.18/46/2021						124.44		
4.3	F.18/47/2021						124.44		
	F.18/48/2021	25-12-2021	22-01-2022	Above Foundation Ch. 30 mt to Ch 56 mts	1.3.6	100 kg/cm2	128.89	127.41	do
	F.18/49/2021						128.89		
4.4	F.18/50/2021						124.44		
	F.18/51/2021	25-12-2021	22-01-2022	Above Foundation Ch. 30 mt to Ch 56 mts	1.3.6	100 kg/cm2	124.44	125.92	do
	F.18/52/2021						128.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

## SD III (QC) , WRD, GOGAL, MARGAO- GOA.

**NAME OF THE WORK:** Improvement to nallah near Vasudev Vernekar at Thana in Cortalim Constituency.

**SAMPLE SENT BY:** AE, SD II, WD II, WRD, Gogol- Margao- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm <sup>2</sup>	Avg. Comp Kg/cm <sup>2</sup>	LETTER No / DATED
5.1	F.18/53/2021						128.89		No. WRD/WD II/ SD II/ F.03/263/2021-22. <b>DATED: 28-12-2021</b>
	F.18/54/2021	24-12-2021	21-01-2022	Above Foundation Ch.0 mt to Ch 30 mts	1.3.6	100 kg/cm <sup>2</sup>	128.89	128.89	
	F.18/55/2021						128.89		
5.2	F.18/56/2021						124.44		do
	F.18/57/2021	24-12-2021	21-01-2022	Above Foundation Ch.0 mt to Ch 30 mts	1.3.6	100 kg/cm <sup>2</sup>	124.44	124.44	
	F.18/58/2021						124.44		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**