

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization of unstable hill slope of nallah/ waterways bank in Sy.No.149/2 at Barmolem in Village Barcem in V.P. Barcem- Quedem of Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm ²	Avg. Comp Kg/cm ²	LETTER No / DATED
1	F.46/06/2021						257.77		No. WRD/WD XII/SD V/
	F.46/07/2021	30-03-2022	6/4/2022	Anchor & Foundation	M 25	kg/cm ²	262.22	259.25	F.15/04/2022-23
	F.46/08/2021						257.77		DATED: 05-04-2022
2	F.46/09/2021						262.22		
	F.46/10/2021	1/4/2022	8/4/2022	Stem & haunch	M 25	kg/cm ²	257.78	260.74	do
	F.46/11/2021						262.22		
3	F.46/12/2021						257.77		
	F.46/13/2021	3/4/2022	10/4/2022	Stem	M 25	kg/cm ²	262.22	259.25	do
	F.46/14/2021						257.77		
4.1	F.46/72/2021						266.67		No. WRD/WD XII/SD V/
	F.46/73/2021	5/4/2022	12/4/2022	Anchor & Foundation	M 25	kg/cm ²	257.78	262.22	F.15/27/2021-22
	F.46/74/2021						262.22		DATED: 12-04-2022
4.2	F.46/75/2021						257.77		
	F.46/76/2021	5/4/2022	12/4/2022	Anchor & Foundation	M 25	kg/cm ²	262.22	259.25	do
	F.46/77/2021						257.77		
4.3	F.46/78/2021						257.77		
	F.46/79/2021	5/4/2022	12/4/2022	Anchor & Foundation	M 25	kg/cm ²	262.22	259.25	do
	F.46/80/2021						257.77		
5.1	F.46/81/2021						257.77		
	F.46/82/2021	6/4/2022	13-04-2022	Anchor & Foundation	M 25	kg/cm ²	262.22	259.25	do
	F.46/83/2021						257.77		
5.2	F.46/84/2021						266.67		
	F.46/85/2021	6/4/2022	13-04-2022	Anchor & Foundation	M 25	kg/cm ²	257.78	262.22	do
	F.46/86/2021						262.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Stabilization of unstable hill slope of nallah/ waterways bank in Sy.No.149/2 at Barmolem in Village Barcem in V.P. Barcem- Quedem of Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.3	F.46/87/2021						257.77		No. WRD/WD XII/SD V/ F.15/27/2021-22 DATED: 12-04-2022
	F.46/88/2021	6/4/2022	13-04-2022	Anchor & Foundation	M 25	kg/cm2	262.22	259.25	
	F.46/89/2021						257.77		
6.1	F.46/90/2021						266.67		do
	F.46/91/2021	7/4/2022	14-04-2022	Haunch & Stem	M 25	kg/cm2	257.78	262.22	
	F.46/92/2021						262.22		
6.2	F.46/93/2021						257.77		do
	F.46/94/2021	7/4/2022	14-04-2022	Haunch & Stem	M 25	kg/cm2	257.78	257.77	
	F.46/95/2021						257.77		
7.1	F.46/96/2021						257.77		do
	F.46/97/2021	8/4/2022	15-04-2022	Stem	M 25	kg/cm2	262.22	259.25	
	F.46/98/2021						257.77		
7.2	F.46/99/2021						257.77		do
	F.46/100/2021	8/4/2022	15-04-2022	Stem	M 25	kg/cm2	262.22	259.25	
	F.46/101/2021						257.77		
8.1	F.46/102/2021						266.67		do
	F.46/103/2021	9/4/2022	16-04-2022	Top Raft Foundation	M 25	kg/cm2	257.78	262.22	
	F.46/104/2021						262.22		
8.2	F.46/105/2021						262.22		do
	F.46/106/2021	9/4/2022	16-04-2022	Top Raft Foundation	M 25	kg/cm2	257.78	260.74	
	F.46/107/2021						262.22		

JUNIOR ENGINEER.

ASSISTANT ENGINEER