

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Bandhara & Improvement to field channels & distributaries in Sy.No. 149 at Gimmona near Shri Rohidas Naik's house in ward No. 1 of V.P. in Priol Constituency in Ponda Taluka.

SAMPLE SENT BY: AE, SD IV, WD XI, WRD, Ponda- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.47/10/2021						115.56		No. WRD/WD XI/ SD IV/
	F.47/11/2021	4/1/2022	11/1/2022	For Foundation	1.2.4	100 kg/cm2	120.00	118.52	W.F. 438/448/2021-22.
	F.47/12/2021						120.00		DATED: 10-01-2022
2	F.47/13/2021						115.56		
	F.47/14/2021	5/1/2022	12/1/2022	For Foundation	1.2.4	100 kg/cm2	120.00	115.56	do
	F.47/15/2021						111.11		
3	F.47/16/2021						115.56		
	F.47/17/2021	6/1/2022	13-01-2022	For Foundation	1.2.4	100 kg/cm2	124.44	117.04	do
	F.47/18/2021						111.11		
4	F.47/19/2021						120.00		
	F.47/20/2021	7/1/2022	14-01-2022	For Foundation	1.2.4	100 kg/cm2	120.00	117.04	do
	F.47/21/2021						111.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER