

**GOVERNMENT OF GOA  
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of protection wall to the nallah in Sy.No. 165 to 200 at Khirbat V.P. Carmona of Salcete Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.52/23/2021						164.44		No. WRD/SD I/WD II/ F.Estt/749/2021-22 <b>DATED:- 21-02-2022</b>
	F.52/24/2021	24-01-2022	21-02-2022		1.2.4	150 kg/cm2	164.44	164.44	
	F.52/25/2021						164.44		
1.2	F.52/26/2021						168.89		do
	F.52/27/2021	24-01-2022	21-02-2022		1.2.4	150 kg/cm2	164.44	165.92	
	F.52/28/2021						164.44		
2.1	F.52/29/2021						164.44		do
	F.52/30/2021	25-01-2022	22-02-2022		1.2.4	150 kg/cm2	160.00	162.96	
	F.52/31/2021						164.44		
2.2	F.52/32/2021						164.44		do
	F.52/33/2021	25-01-2022	22-02-2022		1.2.4	150 kg/cm2	164.44	165.92	
	F.52/34/2021						168.89		
3.1	F.52/35/2021						168.89		do
	F.52/36/2021	26-01-2022	23-02-2022		1.2.4	150 kg/cm2	164.44	165.92	
	F.52/37/2021						164.44		
3.2	F.52/38/2021						164.44		do
	F.52/39/2021	26-01-2022	23-02-2022		1.2.4	150 kg/cm2	160.00	162.96	
	F.52/40/2021						164.44		
4.1	F.52/41/2021						164.44		do
	F.52/42/2021	27-01-2022	24-02-2022		1.2.4	150 kg/cm2	160.00	162.96	
	F.52/43/2021						164.44		
4.2	F.52/44/2021						164.44		do
	F.52/45/2021	27-01-2022	24-02-2022		1.2.4	150 kg/cm2	164.44	165.92	
	F.52/46/2021						168.89		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**

## SD III (QC) , WRD, GOGAL, MARGAO- GOA.

**NAME OF THE WORK:** Construction of protection wall to the nallah in Sy.No. 165 to 200 at Khirbat V.P. Carmona of Salcete Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfond- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
5.1	F.52/47/2021						164.44		No. WRD/SD I/WD II/ F.Estt/749/2021-22 <b>DATED:- 21-02-2022</b>
	F.52/48/2021	28-01-2022	25-02-2022		1.2.4	150 kg/cm2	160.00	162.96	
	F.52/49/2021						164.44		
5.2	F.52/50/2021						164.44		do
	F.52/51/2021	28-01-2022	25-02-2022		1.2.4	150 kg/cm2	164.44	165.92	
	F.52/52/2021						168.89		
6.1	F.52/53/2021						168.89		do
	F.52/54/2021	29-01-2022	26-02-2022		1.2.4	150 kg/cm2	164.44	165.92	
	F.52/55/2021						164.44		
6.2	F.52/56/2021						164.44		do
	F.52/57/2021	29-01-2022	26-02-2022		1.2.4	150 kg/cm2	160.00	162.96	
	F.52/58/2021						164.44		
7.1	F.52/59/2021						164.44		do
	F.52/60/2021	31-01-2022	28-02-2022		1.2.4	150 kg/cm2	160.00	162.96	
	F.52/61/2021						164.44		
7.2	F.52/62/2021						164.44		do
	F.52/63/2021	31-01-2022	28-02-2022		1.2.4	150 kg/cm2	164.44	165.92	
	F.52/64/2021						168.89		
8.1	F.52/65/2021						168.89		do
	F.52/66/2021	1/2/2022	1/3/2022		1.2.4	150 kg/cm2	164.44	167.41	
	F.52/67/2021						168.89		
8.2	F.52/68/2021						168.89		do
	F.52/69/2021	1/2/2022	1/3/2022		1.2.4	150 kg/cm2	164.44	165.92	
	F.52/70/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

## SD III (QC) , WRD, GOGAL, MARGAO- GOA.

**NAME OF THE WORK:** Construction of protection wall to the nallah in Sy.No. 165 to 200 at Khirbat V.P. Carmona of Salcete Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfnd- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
9.1	F.52/71/2021						164.44		No. WRD/SD I/WD II/ F.Estt/749/2021-22 <b>DATED:- 21-02-2022</b>
	F.52/72/2021	2/2/2022	2/3/2022		1.2.4	150 kg/cm2	160.00	162.96	
	F.52/73/2021						164.44		
9.2	F.52/74/2021						164.44		do
	F.52/75/2021	2/2/2022	2/3/2022		1.2.4	150 kg/cm2	164.44	165.92	
	F.52/76/2021						168.89		
10.1	F.52/77/2021						164.44		do
	F.52/78/2021	3/2/2022	3/3/2022		1.2.4	150 kg/cm2	164.44	165.92	
	F.52/79/2021						168.89		
10.2	F.52/80/2021						168.89		do
	F.52/81/2021	3/2/2022	3/3/2022		1.2.4	150 kg/cm2	168.89	167.41	
	F.52/82/2021						164.44		
11.1	F.52/83/2021						164.44		do
	F.52/84/2021	4/2/2022	4/3/2022		1.2.4	150 kg/cm2	164.44	165.92	
	F.52/85/2021						168.89		
11.2	F.52/86/2021						168.89		do
	F.52/87/2021	4/2/2022	4/3/2022		1.2.4	150 kg/cm2	168.89	167.41	
	F.52/88/2021						164.44		
12.1	F.52/89/2021						168.89		do
	F.52/90/2021	5/2/2022	5/3/2022		1.2.4	150 kg/cm2	168.89	167.41	
	F.52/91/2021						164.44		
12.2	F.52/92/2021						168.89		do
	F.52/93/2021	5/2/2022	5/3/2022		1.2.4	150 kg/cm2	164.44	165.92	
	F.52/94/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

## SD III (QC) , WRD, GOGAL, MARGAO- GOA.

**NAME OF THE WORK:** Construction of protection wall to the nallah in Sy.No. 165 to 200 at Khirbat V.P. Carmona of Salcete Taluka.

**SAMPLE SENT BY:** AE, SD I, WD II, WRD, Rawanfnd- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
13.1	F.52/95/2021						164.44		No. WRD/SD I/WD II/ F.Estt/749/2021-22 <b>DATED:- 21-02-2022</b>
	F.52/96/2021	7/2/2022	7/3/2022		1.2.4	150 kg/cm2	160.00	162.96	
	F.52/97/2021						164.44		
13.2	F.52/98/2021						164.44		do
	F.52/99/2021	7/2/2022	7/3/2022		1.2.4	150 kg/cm2	164.44	165.92	
	F.52/100/2021						168.89		
14.1	F.52/101/2021						168.89		do
	F.52/102/2021	8/2/2022	8/3/2022		1.2.4	150 kg/cm2	164.44	165.92	
	F.52/103/2021						164.44		
14.2	F.52/104/2021						164.44		do
	F.52/105/2021	8/2/2022	8/3/2022		1.2.4	150 kg/cm2	160.00	162.96	
	F.52/106/2021						164.44		
15.1	F.52/107/2021						164.44		do
	F.52/108/2021	9/2/2022	9/3/2022		1.2.4	150 kg/cm2	160.00	162.96	
	F.52/109/2021						164.44		
15.2	F.52/110/2021						164.44		do
	F.52/111/2021	9/2/2022	9/3/2022		1.2.4	150 kg/cm2	164.44	165.92	
	F.52/112/2021						168.89		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**