

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Protection wall for nalla in front of the Capela Mae Devote connecting to the main nallah near the residence of Especiosa Fernandes, Bernadetta Fernandes, Joyce Fernandes and Bernardo Reis at Devote in V.P Loutulim in Nuvem Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.57/05/2021						164.44		No.WRD/ SD I/ WD II/ F.Estt/731/2021-22. DATED:- 10-02-2022
	F.57/06/2021	27-01-2022	24-02-2022	Foundation	1.2.4	150 kg/cm2	164.44	164.44	
	F.57/07/2021						164.44		
1.2	F.57/08/2021						168.89		do
	F.57/09/2021	27-01-2022	24-02-2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.57/10/2021						164.44		
2.1	F.57/11/2021						164.44		do
	F.57/12/2021	28-01-2022	25-02-2022	Foundation	1.2.4	150 kg/cm2	160.00	162.96	
	F.57/13/2021						164.44		
2.2	F.57/14/2021						164.44		do
	F.57/15/2021	28-01-2022	25-02-2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	
	F.57/16/2021						168.89		
3.1	F.57/17/2021						168.89		do
	F.57/18/2021	31-01-2022	28-02-2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	
	F.57/19/2021						164.44		
3.2	F.57/20/2021						164.44		do
	F.57/21/2021	31-01-2022	28-02-2022	Wall	1.2.4	150 kg/cm2	160.00	162.96	
	F.57/22/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Protection wall for nalla in front of the Capela Mae Devote connecting to the main nallah near the residence of Especiosa Fernandes, Bernadetta Fernandes, Joyce Fernandes and Bernardo Reis at Devote in V.P Loutulim in Nuvem Constituency.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfond- Goa.

NAME OF THE AGENCY

TESTING PERIOD

28 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPORTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
4.1	F.57/23/2021						164.44		No.WRD/ SD I/ WD II/
	F.57/24/2021	1/2/2022	1/3/2022	Wall	1.2.4	150 kg/cm2	160.00	162.96	F.Estt/731/2021-22.
	F.57/25/2021						164.44		DATED:- 10-02-2022
4.2	F.57/26/2021						164.44		
	F.57/27/2021	1/2/2022	1/3/2022	Wall	1.2.4	150 kg/cm2	164.44	165.92	do
	F.57/28/2021						168.89		
5.1	F.57/29/2021						164.44		
	F.57/30/2021	4/2/2022	4/3/2022	Foundation	1.2.4	150 kg/cm2	160.00	162.96	do
	F.57/31/2021						164.44		
5.2	F.57/32/2021						164.44		
	F.57/33/2021	4/2/2022	4/3/2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	do
	F.57/34/2021						168.89		
5.3	F.57/35/2021						168.89		
	F.57/36/2021	4/2/2022	4/3/2022	Foundation	1.2.4	150 kg/cm2	164.44	165.92	do
	F.57/37/2021						164.44		
6	F.57/38/2021						164.44		
	F.57/39/2021	5/2/2022	5/3/2022	Wall	1.2.4	150 kg/cm2	160.00	162.96	do
	F.57/40/2021						164.44		

JUNIOR ENGINEER.

ASSISTANT ENGINEER