

**GOVERNMENT OF GOA**  
**SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

**NAME OF THE WORK:** Construction of nallah protection wall near the house of Yatish Suresh Naik in Village Panchayat Durbhat Marcaim Constituency.

**SAMPLE SENT BY:** AE, SD IV, WD XI, WRD, Ponda- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.59/05/2021						80.00		No. WRD/WD XI/ SD IV/ F.CF/432/2021-22. <b>DATED: 06-01-2022</b>
	F.59/06/2021	30-12-2021	6/1/2022	Nallah Foundation	1.3.6	70 kg/cm2	80.00	78.52	
	F.59/07/2021						75.56		
2	F.59/08/2021						75.56		do
	F.59/09/2021	31-12-2021	7/1/2022	Nallah Foundation	1.3.6	70 kg/cm2	75.56	77.04	
	F.59/10/2021						80.00		
3	F.59/11/2021						80.00		do
	F.59/12/2021	1/1/2022	10/1/2022	Wall Concrete	1.3.6	70 kg/cm2	80.00	80.00	
	F.59/13/2021						80.00		
4	F.59/14/2021						75.56		do
	F.59/15/2021	3/1/2022	10/1/2022	Wall Concrete	1.3.6	70 kg/cm2	80.00	77.04	
	F.59/16/2021						75.56		
5.1	F.59/17/2021						75.56		do
	F.59/18/2021	5/1/2022	12/1/2022	Wall Concrete	1.3.6	70 kg/cm2	75.56	75.56	
	F.59/19/2021						75.56		
5.2	F.59/20/2021						75.56		do
	F.59/21/2021	5/1/2022	12/1/2022	Wall Concrete	1.3.6	70 kg/cm2	80.00	77.04	
	F.59/22/2021						75.56		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**

**GOVERNMENT OF GOA**

## SD III (QC) , WRD, GOGAL, MARGAO- GOA.

**NAME OF THE WORK:** Construction of nallah protection wall near the house of Yatish Suresh Naik in Village Panchayat Durbhat Marcaim Constituency.

**SAMPLE SENT BY:** AE, SD IV, WD XI, WRD, Ponda- Goa.

**NAME OF THE AGENCY**

**TESTING PERIOD**

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1	F.59/41/2021						75.56		No. WRD/WD XI/ SD IV/
	F.59/42/2021	15-01-2022	22-01-2022	Wall Concrete	1.3.6	70 kg/cm2	80.00	77.04	F.CF/469/2021-22.
	F.59/43/2021						75.56		<b>DATED: 21-01-2022</b>
2	F.59/44/2021						80.00		
	F.59/45/2021	18-01-2022	25-01-2022	Wall Concrete	1.3.6	70 kg/cm2	75.56	78.52	do
	F.59/46/2021						80.00		

**JUNIOR ENGINEER.**

**ASSISTANT ENGINEER**