

GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Open Type Bandhara at Komtat Assoldem in V.P. Barcem Quedem in Quepem Constituency.

SAMPLE SENT BY: AE, SD V, WD XII, WRD, Quepem- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.62/05/2021						115.56		No. WRD/WD XII/SD V/ F.15/176/2021-22. DATED:- 15-02-2022.
	F.62/06/2021	8/2/2022	15-02-2022	LHS & RHS 1st Lift U/s & D/s bandhara	1.2.4	100 kg/cm2	120.00	118.52	
	F.62/07/2021			retaining wall, wing wall & key all			120.00		
1.2	F.62/08/2021						115.56		
	F.62/09/2021	8/2/2022	15-02-2022	LHS & RHS 1st Lift U/s & D/s bandhara	1.2.4	100 kg/cm2	120.00	115.56	do
	F.62/10/2021			retaining wall, wing wall & key all			111.11		
1.3	F.62/11/2021						115.56		
	F.62/12/2021	8/2/2022	15-02-2022	LHS & RHS 1st Lift U/s & D/s bandhara	1.2.4	100 kg/cm2	124.44	117.04	do
	F.62/13/2021			retaining wall, wing wall & key all			111.11		
1.4	F.62/14/2021						120.00		
	F.62/15/2021	8/2/2022	15-02-2022	LHS & RHS 1st Lift U/s & D/s bandhara	1.2.4	100 kg/cm2	120.00	117.04	do
	F.62/16/2021			retaining wall, wing wall & key all			111.11		
2.1	F.62/17/2021						115.56		
	F.62/18/2021	10/2/2022	17-02-2022	LHS & RHS 2nd Lift U/s & D/s bandhara	1.2.4	100 kg/cm2	115.55	117.04	do
	F.62/19/2021			retaining wall, wing wall & key all			120.00		
2.2	F.62/20/2021						115.56		
	F.62/21/2021	10/2/2022	17-02-2022	LHS & RHS 2nd Lift U/s & D/s bandhara	1.2.4	100 kg/cm2	115.56	115.56	do
	F.62/22/2021			retaining wall, wing wall & key all			115.56		
3	F.62/23/2021						160.00		
	F.62/24/2021	11/2/2022	18-02-2022	Pier	1.1.5.3	135 kg/cm2	168.89	162.96	do
	F.62/25/2021						160.00		
4	F.62/26/2021						160.00		
	F.62/27/2021	13-02-2022	20-02-2022	Pier	1.1.5.3	135 kg/cm2	164.44	164.44	do
	F.62/28/2021						168.89		

JUNIOR ENGINEER.

ASSISTANT ENGINEER