

**GOVERNMENT OF GOA
SD III (QC) , WRD, GOGAL, MARGAO- GOA.**

NAME OF THE WORK: Construction of Retaining wall for pond in Curtorim under Sy.No. 567/29, 568/1 and 568/3 at Muxivaddo, Curtorim Salcete Goa.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfnd- Goa.

NAME OF THE AGENCY				TESTING PERIOD		07 days.			
REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
1.1	F.72/05/2021						115.56		No. WRD/SD I/WD II/ F.Estt/709/2021-22 DATED:- 21-01-2022
	F.72/06/2021	15-01-2022	22-01-2022	Foundation	1.2.4	100 kg/cm2	120.00	118.52	
	F.72/07/2021						120.00		
1.2	F.72/08/2021						115.56		do
	F.72/09/2021	15-01-2022	22-01-2022	Foundation	1.2.4	100 kg/cm2	120.00	115.56	
	F.72/10/2021						111.11		
2.1	F.72/11/2021						115.56		do
	F.72/12/2021	17-01-2022	24-01-2022	Foundation	1.2.4	100 kg/cm2	124.44	117.04	
	F.72/13/2021						111.11		
2.2	F.72/14/2021						120.00		do
	F.72/15/2021	17-01-2022	24-01-2022	Foundation	1.2.4	100 kg/cm2	120.00	117.04	
	F.72/16/2021						111.11		
3.1	F.72/17/2021						115.56		do
	F.72/18/2021	18-01-2022	25-01-2022	Foundation & Wall	1.2.4	100 kg/cm2	115.55	117.04	
	F.72/19/2021						120.00		
3.2	F.72/20/2021						115.56		do
	F.72/21/2021	18-01-2022	25-01-2022	Foundation & Wall	1.2.4	100 kg/cm2	115.56	115.56	
	F.72/22/2021						115.56		
4.1	F.72/23/2021						111.11		do
	F.72/24/2021	19-01-2022	26-01-2022	Wall	1.2.4	100 kg/cm2	115.56	115.56	
	F.72/25/2021						120.00		
4.2	F.72/26/2021						115.56		do
	F.72/27/2021	19-01-2022	26-01-2022	Wall	1.2.4	100 kg/cm2	115.56	117.04	
	F.72/28/2021						120.00		

JUNIOR ENGINEER.

ASSISTANT ENGINEER

GOVERNMENT OF GOA

SD III (QC) , WRD, GOGAL, MARGAO- GOA.

NAME OF THE WORK: Construction of Retaining wall for pond in Curtorim under Sy.No. 567/29, 568/1 and 568/3 at Muxivaddo, Curtorim Salcete Goa.

SAMPLE SENT BY: AE, SD I, WD II, WRD, Rawanfnd- Goa.

NAME OF THE AGENCY

TESTING PERIOD

07 days.

REPORT NO	SAMPLE NOS.	CASTING DATE	TESTING DATE	LOCATION OF SAMPLE	MIX PROPOTION	REQUIRED STRENGTH	Comp sth in Kg/cm2	Avg. Comp Kg/cm2	LETTER No / DATED
4.3	F.72/29/2021						115.56		No. WRD/SD I/WD II/
	F.72/30/2021	19-01-2022	26-01-2022	Wall	1.2.4	100 kg/cm2	111.11	117.04	F.Estt/709/2021-22
	F.72/31/2021						124.44		DATED:- 21-01-2022
5.1	F.72/32/2021						115.56		
	F.72/33/2021	20-01-2022	27-01-2022	Wall	1.2.4	100 kg/cm2	120.00	115.56	do
	F.72/34/2021						111.11		
5.2	F.72/35/2021						115.56		
	F.72/36/2021	20-01-2022	27-01-2022	Wall	1.2.4	100 kg/cm2	120.00	115.56	
	F.72/37/2021						111.11		

JUNIOR ENGINEER.

ASSISTANT ENGINEER